



08-12-24 FREDDY'S HCI - N. DURHAM, NC (3211) - RENEW

Project Issue Information

Issue Name : MAU-OA FILTER-REPLACEMENT NEEDED NEXT VISIT

Description : Filter medium degraded, multiple areas are see through. These filters will continue to degrade until they are screens, as they degrade the MAU will temporarily increase CFM, until debris gets stuck in the fan and pushes through to clog your PSP limiting OA into the space. (3)16x20x2 metal filters needed

Created By : National TAB **Assigned To :** National TAB - Kyle Henry

Status : Open

Priority : Urgent **Asset Tag :**

Originated Date : 11/04/2024 - JOASH ALBIN - National TAB

Project Issue File Details



11/04/2024



11/04/2024