

ALL BE RATED WITH ONE INCH THICK LAYER OF INSULATION TO MEET "ZERO INCH CLEARANCE" TO ADJACENT ROOMS. HOOD SHALL BE CERTIFIED BY ETL. HOOD SHALL CONFORM TO UL STANDARD 710, BUILT PER UL 710, AND NSF LISTED.

SHEET NOTES

ALL EXHAUSTING DIFFUSERS AND GRILLES ARE SAME SIZE AS DIFFUSER OR GRILLE UNLESS NOTED OTHERWISE.

NOT SHOWN FOR CLARITY. ALL TAKE-OFFS SHALL INCLUDE FLEXIBLE TAKE-OFF TAIL FOR FLEXIBLE DUCT INSTALLATION REQUIREMENTS.

1 MECHANICAL RENOVATION FLOOR PLAN
SCALE: 1/4"=1'-0"

