

Kitchen Exhaust 8	Occupied : (Pass) Control :(Pass)
Comment	Restroom exhaust fan - EC circuit 8
Kitchen 32	Occupied : (Pass) Control :(Pass)
Comment	BOH prep lights - EC circuit 32
Kitchen 34	Occupied : (Pass) Control :(Pass)
Comment	FOH Cook and Serve Line - EC circuit 34
Vestibule Hall 28	Occupied : (Pass) Control :(Pass)
Comment	Entry Vestibule and Restroom Hall - EC circuit 28
BOH EXT light	Occupied : (Pass) Control :(Pass)
Comment	Exterior Wall Sconces above sprinkler and rear kitchen doors
DT signs 41	Occupied : (Pass) Control :(Pass)
Comment	Drive Thru Entry: "pick up window only" sign
Signs 25	Occupied : (Pass) Control :(Pass)
Comment	Drive Thru and Window "Shake Shack" signage (2 signs) - EC circuit 25
Signs 21	Occupied : (Pass) Control :(Pass)
Comment	South Facing Drive Thru entry "Shake Shack" signage (1 sign) - EC circuit 21
Signs 19	Occupied : (Pass) Control :(Pass)
Comment	Indoor "Stand for Something" Signage
I/V beam	Occupied : (Pass) Control :(Pass)
Comment	Customer Serve line spot lights and strip lighting for customer facing wall and restroom signage
EXT Sconce 29	Occupied : (Pass) Control :(Pass)
Comment	Outdoor Patio and Drive Thru Exit Wall sconces
LOCAL ZONE LIGHTING - NON LUTRON-VIVE CONTROLLED	
Emergency lights	Occupied : (Pass) Control :(Pass)
Comment	Emergency lights on during loss of power in zones or throughout the entire building
Office Lights	Occupied : (Pass) Control :(Pass)
Comment	Local Switch
Exit Lights	Occupied : (Pass) Control :(Pass)
Comment	Always on

Sprinkler room lights

Occupied : (Pass) Control :(Pass)

Comment

local switch

Restroom lights

Occupied : (Pass) Control :(Pass)

Comment

Ceiling Sensor