



## Shake Shack (Oak Lawn, IL) - Commissioning

### CheckList Information

**Name :** (FPT) Lighting **Status :** NotSubmitted  
**Assigned Organization :** National TAB **Asset :**  
**Requesting Organization :** National TAB

### CheckList Item Details

#### STARTUP DETAILS

Date Completed, Tech Name, Tech Phone Number	8/17/21, Jordan, 312-244-0520
Updates completed	Pico Firmware
Password	Sh@keSh@ck!!11
Occupied Time on / Unoccupied Time Off	6:00 am - All Interior and Exterior Lights On. / 12:00 AM (midnight) - All Interior and Exterior lights Off
Dimming	No dimming available. All lights are 100% on or off based on schedule or manual PICO override

#### PICO PROGRAMMING

PICO 1: 2 BUTTON	Occupied : (Pass) Control :(Pass)
Comment	All interior lights manual override "on" and "off"
PICO 2: 2 BUTTON	Occupied : (Pass) Control :(Pass)
Comment	All Exterior lights manual override "on" and "off"

#### LUTRON-VIVE LIGHT ZONES

Dining 24	Occupied : (Pass) Control :(Pass)
Comment	South Dining - 2 rows on EC circuit 24
Dining 26	Occupied : (Pass) Control :(Pass)
Comment	Center and North Dining - 3 rows on EC circuit 26
Dining 30	Occupied : (Pass) Control :(Pass)
Comment	South Dining - Under Soffit - EC circuit 30
Patio Stringer 33	Occupied : (Pass) Control :(Pass)
Comment	All Patio Stringer Lights - EC circuit 33

Kitchen Exhaust 8	Occupied : (Pass) Control :(Pass)
Comment	Restroom exhaust fan - EC circuit 8
Kitchen 32	Occupied : (Pass) Control :(Pass)
Comment	BOH prep lights - EC circuit 32
Kitchen 34	Occupied : (Pass) Control :(Pass)
Comment	FOH Cook and Serve Line - EC circuit 34
Vestibule Hall 28	Occupied : (Pass) Control :(Pass)
Comment	Entry Vestibule and Restroom Hall - EC circuit 28
BOH EXT light	Occupied : (Pass) Control :(Pass)
Comment	Exterior Wall Sconces above sprinkler and rear kitchen doors
DT signs 41	Occupied : (Pass) Control :(Pass)
Comment	Drive Thru Entry: "pick up window only" sign
Signs 25	Occupied : (Pass) Control :(Pass)
Comment	Drive Thru and Window "Shake Shack" signage (2 signs) - EC circuit 25
Signs 21	Occupied : (Pass) Control :(Pass)
Comment	South Facing Drive Thru entry "Shake Shack" signage (1 sign) - EC circuit 21
Signs 19	Occupied : (Pass) Control :(Pass)
Comment	Indoor "Stand for Something" Signage
I/V beam	Occupied : (Pass) Control :(Pass)
Comment	Customer Serve line spot lights and strip lighting for customer facing wall and restroom signage
EXT Sconce 29	Occupied : (Pass) Control :(Pass)
Comment	Outdoor Patio and Drive Thru Exit Wall sconces
<b>LOCAL ZONE LIGHTING - NON LUTRON-VIVE CONTROLLED</b>	
Emergency lights	Occupied : (Pass) Control :(Pass)
Comment	Emergency lights on during loss of power in zones or throughout the entire building
Office Lights	Occupied : (Pass) Control :(Pass)
Comment	Local Switch

Exit Lights	Occupied : (Pass) Control :(Pass)
Comment	Always on
Sprinkler room lights	Occupied : (Pass) Control :(Pass)
Comment	local switch
Restroom lights	Occupied : (Pass) Control :(Pass)
Comment	Ceiling Sensor