



Shake Shack (Oak Lawn, IL) - Commissioning

CheckList Information

Name :	(FPT) Restroom Exhaust Fan	Status :	NotSubmitted
Assigned Organization :	National TAB	Asset :	
Requesting Organization :	National TAB		

CheckList Item Details

RESTROOM FAN

Lutron Vive system controls fan on/off	Occupied : (Pass) Control :(Pass)
Comment	
TAB report indicates fan is balanced and performing below the nameplates full load values	Occupied : (Pass) Control :(Pass)
Comment	
With HVAC and exhaust fan running, close bathroom doors. Are the bathrooms negative to adjacent restroom hall area	Occupied : (Pass) Control :(Pass)
Comment	Slight negative draft can be felt - restrooms are negative to adjacent hall space