



Comfort. Under control.

05-09 Shake Shack #1352 (Chesterfield, MO) COMMISSIONING


Project Issue Information

Issue Name : EC- receptacle wall plates missing
Description : cover plates missing behind cooling equipment
Created By : National TAB **Assigned To :** Akron Electric - Patrick Clancy
Status : Open
Originated Date : 05/23/2022 - Dan Hertenstein - National TAB

Project Issue File Details



Outletgriddle.jpeg



Outletfryer.jpeg