



Comfort. Under control.

05-09 Shake Shack #1352 (Chesterfield, MO) COMMISSIONING

Project Issue Information

Issue Name : Restroom EF timer does not work
Description : Restroom EF runs constantly and does not turn off with timer.
Created By : National TAB **Assigned To :** National TAB - Dan Hertenstein
Status : Open
Originated Date : 06/06/2022 - Travis Halter - National TAB

Project Issue File Details



thumbnail_image0.jpg

Project Issue Response Details

- 06/08/2022 National TAB - Dan Hertenstein
 - Timer clock is installed but did not shut-off when set to unoccupied time. Also, the timer clock will loose power if the building has loss of power and the clock will need to be manually reset to correct time afterward.