



Comfort. Under control.

05-09 Shake Shack #1352 (Chesterfield, MO) COMMISSIONING

Project Issue Information

Issue Name : WH malfunction signs
Description : WH malfunction signs not located during last inspection
Created By : National TAB **Assigned To :** Akron Electric - Patrick Clancy
Status : Open
Originated Date : 06/08/2022 - Dan Hertenstein - National TAB

Project Issue File Details

PROVIDE AQUASTATS SET TO ENERGIZE MALFUNCTION INDICATOR LIGHT WHEN WATER HEATER OUTLET TEMPERATURE DROPS BELOW 120°F AND DE-ENERGIZE LIGHT AT OR ABOVE 125°F.

WATER HEATER A WATER HEATER B LIFT VALVE

WATER HEATER LIGHT TAG

Ⓐ Ⓑ

INSTRUCTION SIGN

ATTENTION

LIGHT INDICATES WATER HEATER MALFUNCTION. WHEN LIGHT IS ON TURN VALVE WITH THE TAG THAT MATCHES THE TAG BELOW THE LIGHT. SO THAT THE LEVER IS PERPENDICULAR TO PIPING AND HAVE MANAGEMENT CALL FOR SERVICE.

PROVIDE TAGS MOUNTED BELOW EACH MALFUNCTION INDICATOR LIGHT AND HANGING FROM HOT WATER SHUT-OFF VALVES. LABEL TAGS AS INDICATED ABOVE.

MALFUNCTION INDICATOR LIGHT

DESCRIPTION: 120V, STEADY-ON RED SIGNALING LIGHT WITH THREADED BASE AND SHATTER RESISTANT POLY-CARBONATE LENS. UL LISTED

- EDWARDS #125 SERIES
- FEDERAL SIGNAL #P22 SERIES

Ⓒ WH - INDICATOR TAGS

WH_MALFUNCTION_INDICATOR_AND_SIGN_r1.PNG