



Comfort. Under control.

05-09 Shake Shack #1352 (Chesterfield, MO) COMMISSIONING

Project Issue Information

Issue Name : access doors properly insulated and tagged
Description : Access doors need to be properly insulated and tagged
Created By : National TAB **Assigned To :** Crystal Heating & Cooling - Billy Gray
Status : Pending
Originated Date : 04/29/2022 - Dan Hertenstein - National TAB

Project Issue File Details



Accessdoor.jpeg

Project Issue Response Details

- 06/08/2022 National TAB - Dan Hertenstein
 - CxA needs to go back to site to confirm the doors have been insulated and tagged "clean-out". Insulation needs to be applied so that hood cleaner can easily replace after each cleaning