



MERCH PICK-UP

COVER 36x20 W/ 1/2" WIRE MESH ON TOP OF DUCT (SEE DETAIL HSD-1/MS.1)

FURNITURE 176

LAMP DECK COVER 36x20 W/ 1/2" WIRE MESH ON TOP OF DUCT (SEE DETAIL HSD-1/MS.1)

NOTE TEMPERATURE SENSOR WITH SLIDE BAR ADJUST OVERSIDE TO PERMIT ADJUSTMENT FOR ROSE PHARMACY. (LINE F 40834)

COVER 36x20 W/ 1/2" WIRE MESH ON TOP OF DUCT (SEE DETAIL HSD-1/MS.1)

ROUTE DUCT TO JEWELRY AREA. ROUTE DUCT TO FUTURE LAYOUT.

COVER 36x12 W/ 1/2" WIRE MESH ON TOP OF DUCT (SEE DETAIL HSD-1/MS.1)

2.24x10 W/ 1/2" WIRE MESH ON TOP OF DUCT (SEE DETAIL HSD-1/MS.1)

FAN FOR GOLDSMITH ROOM. DUCTWORK BY OTHERS.

TEMPERATURE PROBE IN LOCKBOX FOR HSD-12 INSTALLED 5'-0" AFF.

COVER 36x20 W/ 1/2" WIRE MESH ON TOP OF DUCT (SEE DETAIL HSD-1/MS.1)

TEMPERATURE PROBE FOR RTU - 1, 2, 4, 6, 9 & 10 INSTALLED 7'-6" AFF. ON COLUMN

NOTE THE TWO SENSORS MUST BE INSTALLED APART BECAUSE THE HUMIDITY SENSOR PRODUCES HEAT

HUMIDITY SENSOR INSTALLED 7'-6" AFF. ON COLUMN

TEMPERATURE PROBE IN LOCKBOX FOR HSD-12 INSTALLED 5'-0" AFF.

COVER 28x12 W/ 1/2" WIRE MESH ON TOP OF DUCT (SEE DETAIL HSD-1/MS.1)

NOTE AIR COOLED PROTECTIVE UNIT "Y" CONNECTED TO RTU-2 HEAT RECLAIM CONT.

NOTE AIR COOLED PROTECTIVE UNIT "Y" CONNECTED TO RTU-2 HEAT RECLAIM CONT.

COVER 28x12 W/ 1/2" WIRE MESH ON TOP OF DUCT (SEE DETAIL HSD-1/MS.1)

switch

BOOKS & MASS 80

HOUSEHOLD 512

SCHOOL & OFFICE 92'

KITCHEN PLACE 392'

PETS 2444

TOYS 184'

BABY WORLD 248'

SEASONAL 164'

fm jewelry

SNACK/COOKIE/CRACKER 247'

JUICE/SC 104'

CHECKSTANDS

1 HVAC - FLOOR PLAN SCALE: 3/32" = 1'-0"