

### AIR BALANCE SCHEDULE

UNIT	HVAC SUPPLY		HVAC RETURN		HVAC OUTDOOR		OA %		HOOD MAKE-UP		HOOD EXHAUST		GENERAL EXH.			
	DESIGN	ACTUAL	DESIGN	ACTUAL	DESIGN	ACTUAL	DESIGN	ACTUAL	DESIGN	ACTUAL	DESIGN	ACTUAL	DESIGN	ACTUAL		
WSHP-1	20 TONS	UPPER DINING	-	5360	#VALUE!	5360		0	#VALUE!	0.0%						
WSHP-2	20 TONS	BAR	-	6697	#VALUE!	6697		0	#VALUE!	0.0%						
HP-3	3 TONS	2ND FLOOR PRIVATE D	-	1374	#VALUE!	1374			#VALUE!	0.0%						
HP-4	5 TONS	FRONT KITCHEN	-	1823	#VALUE!	1823			#VALUE!	0.0%						
HP-5	3 TONS	WINE	-	1441	#VALUE!	1441			#VALUE!	0.0%						
HP-6	3 TONS	SOUTH DINING	-	1223	#VALUE!	1223			#VALUE!	0.0%						
HP-7	3 TONS	PRIVATE DINING		798		0			#DIV/0!	0.0%						
HP-8	5 TONS	LOBBY / RR		1598		0			#DIV/0!	0.0%						
HP-9	5 TONS	REAR KITCHEN		1697						0.0%						
HP-10	UNKNOWN	SOUTH DINING HOST WALL		831						0.0%						
RTU-1		STAIRWELL		1155				0		0.0%						
RTU-2	5 TONS	POOL SOUTH		2309				0		0.0%						
RTU-3	5 TONS	POOL NORTH	-	2269	#VALUE!	2269		0	#VALUE!	0.0%						
KEF-1		HOOD-1 AND HOOD 2										7214				
KEF-2		DISH HD-3										0				
MAU		HOOD-1 AND HOOD 2								4617						
<b>TOTALS</b>			0	28575	#VALUE!	28575	0	0			0	4617	0	7214	0	0

#### NET BUILDING AIRFLOW CALCULATION

TOTALS	DESIGN	ACTUAL
TOTAL OA	0	4617
TOTAL EXHAUST	0	7214
<b>NET AIRFLOW</b>	<b>0</b>	<b>-2597</b>

DOOR TESTED	BUILDING PRESSURE MEASUREMENTS (IN. H2O)
FRONT	
SIDE	
REAR	
<b>AVERAGE</b>	<b>#DIV/0!</b>

#### FINAL CHECKS

ACTUAL NET AIRFLOW COINCIDES WITH DESIGN: !

MEASURED PRESSURES COINCIDES WITH ACTUAL NET AIRFLOW:

PRESSURE FALLS WITHIN IMC TOLERANCE OF +/-0.02" W.C.

NOTES: