

# PlanGrid Task Report - Jan 10, 2025

Prepared by Will T

Jan 10, 2025

## Description

1 task in this report.

# #593 [UNIT 999][EXIST] (MISC) RTU-3 alarm

Status

Open

Type

Planned Work

List

TAB Punch List

Description

AC-3 has an active alarm. The alarm is (24) Compressor 2 low pressure switch. MC to evaluate and fix as required.

Assignees

dmeekins@thebannettgroup.com  
dpagenkopf@thebannettgroup.com

Watchers

dmeekins@thebannettgroup.com  
dpagenkopf@thebannettgroup.com  
tyouells@nationaltab.com

Start Date

Jun 13, 2024

Created

Jun 13, 2024 1:32 PM  
tyouells@nationaltab.com

Last Updated

Jan 10, 2025 2:06 PM

Sheet

M7.1

I SECTION CS600 - MECHANICAL SPECIFICATIONS	
1.01 GENERAL	1.01 CONTRACTOR SHALL BE RESPONSIBLE FOR THE PROTECTION OF ALL EXISTING UTILITIES AND STRUCTURES TO REMAIN. CONTRACTOR SHALL BE RESPONSIBLE FOR THE PROTECTION OF ALL EXISTING UTILITIES AND STRUCTURES TO REMAIN.
1.02 MATERIALS	1.02 CONTRACTOR SHALL SUBMIT ALL MATERIALS AND EQUIPMENT TO THE ENGINEER FOR APPROVAL PRIOR TO INSTALLATION. ALL MATERIALS AND EQUIPMENT SHALL BE NEW UNLESS OTHERWISE SPECIFIED.
1.03 LABOR	1.03 CONTRACTOR SHALL EMPLOY ADEQUATE NUMBER OF SKILLED AND UN-SKILLED LABORERS TO COMPLETE THE WORK IN ACCORDANCE WITH THE SCHEDULED PROGRAM.
1.04 PROTECTION	1.04 CONTRACTOR SHALL BE RESPONSIBLE FOR THE PROTECTION OF ALL EXISTING UTILITIES AND STRUCTURES TO REMAIN. CONTRACTOR SHALL BE RESPONSIBLE FOR THE PROTECTION OF ALL EXISTING UTILITIES AND STRUCTURES TO REMAIN.
1.05 TESTING	1.05 CONTRACTOR SHALL BE RESPONSIBLE FOR THE TESTING AND COMMISSIONING OF ALL EQUIPMENT AND SYSTEMS. CONTRACTOR SHALL SUBMIT A TESTING AND COMMISSIONING PLAN TO THE ENGINEER FOR APPROVAL PRIOR TO TESTING.
1.06 SAFETY	1.06 CONTRACTOR SHALL MAINTAIN SAFE WORKING CONDITIONS AT ALL TIMES. CONTRACTOR SHALL BE RESPONSIBLE FOR THE SAFETY OF ALL PERSONNEL ON THE JOB SITE.
1.07 CLEANUP	1.07 CONTRACTOR SHALL MAINTAIN THE JOB SITE CLEAN AT ALL TIMES. CONTRACTOR SHALL BE RESPONSIBLE FOR THE REMOVAL OF ALL DEBRIS AND WASTE FROM THE JOB SITE.
1.08 WARRANTY	1.08 CONTRACTOR SHALL PROVIDE A WARRANTY FOR ALL WORKMANSHIP AND MATERIALS. THE WARRANTY SHALL BE IN ACCORDANCE WITH THE REQUIREMENTS OF THE CONTRACT DOCUMENTS.

## Comments

Task re-opened. AC-3 is a Lennox core unit. picture attached is a Lennox Prodigy board. Verify AC-3 core app is not showing any alarms.

Stephen Tassinaro Jan 10, 2025


## Photos



Pic 4  
**Aubrey Devonshire**  
Jun 19, 2024 7:30 AM



IMG\_7008  
**Tyler Youells**  
Jun 13, 2024 1:36 PM



IMG\_7008  
Tyler Youells  
Jun 13, 2024 1:36 PM