

SEE NOTE.
DRAWING IS ON
NEXT PAGE

NOTE: THESE ARE
THE DUCTS FOR
THE CONDENSER
FAN. NO AIRFLOW
TESTING
REQUIRED BUT
ENSURE THAT THE
MOTORIZED
DAMPERS ARE
FUNCTIONAL.

NOTE: THESE ARE
THE DUCTS FOR
THE CONDENSER
FAN. NO AIRFLOW
TESTING
REQUIRED BUT
ENSURE THAT THE
MOTORIZED
DAMPERS ARE
FUNCTIONAL.

NOTE: SEE SHEET M-002 FOR
SEQUENCE OF OPERATION

SEE NOTE.
DRAWING IS ON
NEXT PAGE

GROUND FLOOR HVAC PLAN

Scale: 1/4"=1'-0"

Drawing: M-201
Detail: 01

