



Comfort. Under control.

11-21 CULVERS - PUNTA GORDA, FL

Project Issue Information

Issue Name : RTU#2 motor access door is damaged.

Description : The door is bent and is starting to shear on sides. Mechanical has ordered replacement door, but it has not yet arrived.

Created By : National TAB

Assigned To : National TAB - Will Turnbough

Status : Open

Originated Date : 11/28/2022 - Ian Fuller - National TAB

Project Issue File Details



Doorinside.jpeg



Dooroutside.jpeg