

National TAB

Project: First Financial Bank Roselawn (Cincinnati, OH)
Address: 7152 Reading Road Cincinnati, OH 45237

Asset: EF-1

Area: WOMENS RR 114

Unit Data	
MFG	PENBARRY
Model Num	ZT
Serial Num	B23AX06277
Type	CEILING

Motor Data	
Motor MFG	FASCO
Frame	NL
Horsepower	15W
Motor Rpm	1400
Phase	1
Voltage (rated)	115
Amperage (rated)	0.74
Service Factor	1

Test Data		
	Design	Actual
CFM	70	77
Fan RPM	900	1400
RL Voltage	120	118.3
RL Amperage		0.71
Suction ESP		NO ACCESS
Total ESP	0.25	NO ACCESS

National TAB

Project: First Financial Bank Roselawn (Cincinnati, OH)
Address: 7152 Reading Road Cincinnati, OH 45237

Asset: EF-2

Area: MENS RR 115

Unit Data	
MFG	PENNBARRY
Model Num	ZT
Serial Num	B23AX06278
Type	CEILING

Motor Data	
Motor MFG	FASCO
Frame	NL
Horsepower	15W
Motor Rpm	1400
Phase	1
Voltage (rated)	115
Amperage (rated)	0.74
Service Factor	1

Test Data		
	Design	Actual
CFM	70	76
Fan RPM	900	1400
RL Voltage	120	118.9
RL Amperage		0.7
Suction ESP		NO ACCESS
Total ESP	0.25	NO ACCESS

National TAB

Project: First Financial Bank Roselawn (Cincinnati, OH)
Address: 7152 Reading Road Cincinnati, OH 45237

Asset: EF-3

Area: JAN CLOSET 113

Unit Data	
MFG	PENNBARRY
Model Num	ZT
Serial Num	B23AX06276
Type	CEILING

Test Data		
	Design	Actual
CFM	75	78
Fan RPM	900	1400
RL Voltage	120	118.4
RL Amperage		0.72
Suction ESP		NO ACCESS
Total ESP	0.25	NO ACCESS

Motor Data	
Motor MFG	FASCO
Frame	NL
Horsepower	15W
Motor Rpm	1400
Phase	1
Voltage (rated)	115
Amperage (rated)	0.74
Service Factor	1