

KEYNOTES

- 1 REBALANCE EXISTING SUPPLY AIR DIFFUSER TO 90 CFM
- 2 REBALANCE EXISTING RETURN AIR REGISTER TO 75 CFM
- 3 REBALANCE EXISTING OUTDOOR AIR SUPPLY TO 80 CFM
- 4 REBALANCE EXISTING OUTDOOR AIR SUPPLY TO 90 CFM
- 5 REBALANCE EXISTING OUTDOOR AIR SUPPLY TO 60 CFM
- 6 BALANCE OUTDOOR AIR SUPPLY TO 90 CFM
- 7 BALANCE OUTDOOR AIR SUPPLY TO 65 CFM
- 8 PROVIDE MINIMUM 3/4" AC DRAIN AND ROUTE AS REQUIRED TO CONNECT TO EXISTING AC DRAINS.

