

National TAB Intelligence

1329 E Kemper Rd, Suite 4210 – Cincinnati, OH 45246

Cincinnati, OH | Kansas City, MO | Charlotte, NC

D: (513) 889 8214 • O: (855) 682 6822 ext. 1

www.nationaltab.com • [linkedin](#) • [facebook](#) • [twitter](#)

From: Gary Rudd <grudd@core-1.com>

Sent: Thursday, February 26, 2026 8:08 AM

To: Joe Hertenstein <joe.hertenstein@captiveaire.com>; Austin McFall <austin.mcfall@captiveaire.com>; Nick Payne <nickp@nationaltab.com>; Jennifer Burns <jennifer@nationaltab.com>

Cc: Jason McCoy <jmccoy@core-1.com>

Subject: Re: Zingaro - Mechanical Drawings

This is approved lets get it done

Gary Rudd | Project Manager

7446 Jager Court | Cincinnati, Ohio 45230

C: 513.616.4765 O: 513.731.1771

Grudd@core-1.com | www.core-1.com

We create lasting partnerships building & developing Real Estate.

From: Joe Hertenstein <joe.hertenstein@captiveaire.com>

Sent: Wednesday, February 25, 2026 11:53 AM

To: Gary Rudd <grudd@core-1.com>; Austin McFall <austin.mcfall@captiveaire.com>; Nick Payne <nickp@nationaltab.com>; Jennifer Burns <jennifer@nationaltab.com>

Cc: Jason McCoy <jmccoy@core-1.com>

Subject: RE: Zingaro - Mechanical Drawings

Gary

To do testing & Balance & try to adjust outside air & total flow it looks like a full days work. The cost would be \$1200. Let me know if this is approved & I will have [@Jennifer Burns](#) send a formal proposal so you can give National TAB a PO. If it ends up being less time, I can reduce the price, but I am going to figure a full day to start.

I just want to make sure you are not wasting your money & verify that Daryl & his team has put balancing dampers in the outside air duct. Make sure he knows 100% sure if he did or not. The drawings are not clear if it was required or not. I will also reach out to Dave King & find out what he knows.

[@Nick Payne](#) if we do this, it would be Friday, we need to work out the details so its not a wasted trip for Gary.

Sincerely,

Joe Hertenstein Applications Engineer

Representative of Captive Aire

(Region 120 Team Member)

1329 East Kemper Rd, Ste 4210. Cincinnati, OH 45246

c: 513-678-0393

Service Support: <https://support.captiveaire.com>