



- KEYED NOTES:**
- ① EXISTING UNIT TO BE REMOVED & REPLACED & EXISTING CURBS TO REMAIN
  - ② CONNECT NEW CONDENSATE TO EXISTING
  - ③ CONNECT NEW GAS TO EXISTING
  - ④ ADAPTOR CURBS REQUIRED
  - ⑤ EXISTING EQUIPMENT TO REMAIN
  - ⑥ REMOVE FAN & CAP CURB. INSULATE CAP WITH MIN 2" POLYSTYRENE INSULATION
  - ⑦ EXISTING PAINT BOOTH MAKE UP AIR UNIT TO REMAIN
  - ⑧ EXISTING PAINT BOOTH EXHAUST TO REMAIN
  - ⑨ EXISTING UNIT & CURB REPLACED WITH NEW UNIT ON NEW CURB

