



MEAL DELIVERY CANOPY, SEE ARCHITECTURAL.

FROM OUTSIDE FACE OF EXTERIOR WALL FRAMING

TYPE FF FILTERED RETURN GRILLE LOCATED IN LAY-IN CEILING ADJACENT TO ACH2. GRILLE IS NOT DUCTED.

TO ACH3 SENSOR #2, SEE ZIM-701. COORD. EXACT LOCATION OF SENSORS WITH SIGNAGE.

TAP SUPPLY DUCTS FOR ACH3 INTO SIDE OF PLENUM DROP. NO TURNING VANES AT SUPPLY DROP FOR ACH3.

SEAL PENETRATIONS IN DRAFTSTOPPING CURTAIN AIR-TIGHT REFER TO ARCH DRAWINGS FOR LOCATION AND CONSTRUCTION OF DRAFTSTOPPING CURTAIN.