



SEAL PENETRATIONS IN DRAFT STOPPING CURTAIN AIR-TIGHT. REFER TO ARCH DRAWINGS FOR LOCATION AND CONSTRUCTION OF DRAFTSTOPPING CURTAIN.

FROM OUTSIDE FACE OF EXTERIOR WALL FRAMING

DELIVERY  
Y. SEE  
ECTURAL.

2154  
HOOD#2

AD#1

EQUIPMENT AND DUCTWORK PLAN

TYPE 'FF' FILTERED RETURN GRILLE LOCATED IN LAY-IN CEILING ADJACENT TO AD#2. GRILLE IS NOT DUCTED.

TO AC#3 SENSOR#2. SEE 2/M-701. COORD. EXACT LOCATION OF SENSORS WITH SIGNAGE.

TAP SUPPLY DUCTS FOR AC#3 INTO SIDE OF PLENUM DROP. NO TURNING VANES AT SUPPLY DROP FOR AC#3.