## VIROGUARD SCHEDULE

| TAG | QUANITITY | DESCRIPTION | DUCT CONNECTION SIZE | FAN | FURNISHED BY | INSTALLED BY | BASIS FOR DESIGN MANUFACTURER |
|---|---|---|---|---|---|---|---|
| VG-1 | 1 | VIROGUARD HOOD EXHAUST FAN ROOFTOP CONTAINMENT SYSTEM | 18" X 18" | CAPTIVE-AIRE DU240HFA | TDC | GC | ENVIROMATIC |

## GRILLS, REGISTERS, AND DIFFUSERS SCHEDULE

| TAG | DESCRIPTION | FACE SIZE | MATERIAL | FINISH | MOUNTING | FURNISHED BY | INSTALLED BY | BASIS FOR DESIGN | | NOTES |
|---|---|---|---|---|---|---|---|---|---|---|
| | | | | | | | | MANUFACTURER | MODEL | |
| BS1 | BATHROOM AIR PURIFICATION UNIT | 5.44" X 16" | ALUMINUM | STAINLESS STEEL | GYP CEILING | TUV | GC | RGF ENVIRONMENTAL GROUP | BRU ASSEMBLY | SEE ELECTRICAL SHEETS FOR CONNECTION INFORMATION |
| CD1 | PERFORATED CEILING DIFFUSER | 24" X 24" | ALUMINUM | WHITE | LAY-IN CEILING | GC | GC | NAILOR | 4320A TYPE L | PROVIDE INTEGRAL OBD |
| CD2 | PERFORATED CEILING DIFFUSER | 12" X 12" | ALUMINUM | WHITE | GYP CEILING | GC | GC | NAILOR | 4320A TYPE S | PROVIDE INTEGRAL OBD, REMOVE 4-WAY DEFLECTOR |
| ER1 | PERFORATED CEILING EXHAUST | 12" X 12" | ALUMINUM | WHITE | GYP CEILING | GC | GC | NAILOR | 4330R TYPE S | PROVIDE INTEGRAL OBD |
| RG1 | PERFORATED CEILING RETURN | 48" X 24" | ALUMINUM | WHITE | LAY-IN CEILING | GC | GC | NAILOR | 4330R TYPE L | |
| RG2 | 0° FIXED BLADE RETURN GRILLE | SEE NECK SIZE | ALUMINUM | WHITE | WALL | GC | GC | NAILOR | 51FH | |
| SR1 | ADJUSTABLE TURBO NOZZLE | SEE NECK SIZE | ALUMINUM | WHITE | WALL | GC | GC | SEIHO | NT14 | PROVIDE FACE-ACCESSIBLE OBD |
| SR2 | DOUBLE DEFLECTION SUPPLY REGISTER | SEE NECK SIZE | ALUMINUM | WHITE | WALL | GC | GC | NAILOR | 51DH | PROVIDE INTEGRAL OBD |

## FAN SCHEDULE

| TAG | DRIVE TYPE | EXHAUST FLOW [CFM] | E.S.P. [in W.C.] | WEIGHT [lbs] | ELECTRICAL | | FURNISHED BY | INSTALLED BY | BASIS FOR DESIGN | | REMARKS |
|---|---|---|---|---|---|---|---|---|---|---|---|
| | | | | | MOTOR POWER | V/P/H | | | MANUFACTURER | MODEL | |
| EF-1 | DIRECT | 3200 CFM | 1.20 in-wg | 400 | 3 HP | 208/3/60 | HS | GC | CAPTIVE-AIRE | DU240HFA | FURNISHED WITH DISCONNECT AND VENTED ROOF CURB |
| EF-2 | DIRECT | 150 CFM | 0.60 in-wg | 100 | 0.18 HP | 120/1/60 | HS | GC | CAPTIVE-AIRE | DR12HFA | FURNISHED WITH DISCONNECT, VARIABLE SPEED CONTROLLER, BACKDRAFT DAMPER AND ROOF CURB |

## MAKEUP AIR UNIT SCHEDULE

| TAG | DESCRIPTION | AIRFLOW | | HEATING CAPACTIY | | | | APPROXIMATE WEIGHT [lbs] | ELECTRICAL | | FURNISHED BY | INSTALLED BY | BASIS FOR DESIGN | | REMARKS |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | SUPPLY FLOW [CFM] | E.S.P. [in. W.C.] | INPUT [MBH] | OUTPUT [MBH] | MAXIMUM TURNDOWN | EAT | | MOTOR POWER | V/P/H | | | MANUFACTURER | MODEL | |
| MAU-1 | MAKEUP AIR UNIT | 1950 | 0.80 | 225 | 220 | 12.5:1 | 10 °F | 650 | 2 HP | 208/3/60 | HS | GC | CAPTIVE-AIRE | A1-D.250-15D | FURNISHED WITH DISCONNECT, ROOF CURB, SCREEN INTAKE, AND WASHABLE ALUMINUM FILTERS |

## CONDENSING UNIT SCHEDULE

| TAG | DESCRIPTION | NOMINAL CAPACITY [TONS] | NUMBER OF COMPRESSORS | NUMBER OF CIRCUITS | REFRIGERANT TYPE | REFRIGERANT CHARGE | WEIGHT | ELECTRICAL | | | FURNISHED BY | INSTALLED BY | BASIS FOR DESIGN | | REMARKS |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | | | | | | | MOCP | FLA | V/P/H | | | MANUFACTURER | MODEL | |
| CU-1 | WALK-IN COOLER REMOTE CONDENSING UNIT | -- | 1 | 1 | R-404A | | 200 | 15 A | 6.5 A | 208/3/60 | WCS | GC | HARFORD | PCL99MOP-3 | FURNISHED WITH WALK-IN COOLER |
| CU-2 | ICE MAKER - REMOTE CONDENSER | -- | 0 | 1 | R-404A | 11 lbs 7.4 oz | 100 | | | 120/1/60 | KES | GC | - | - | FURNISHED WITH ICE MAKER |
| CU-3 | ICE MAKER - REMOTE CONDENSER | -- | 0 | 1 | R-404A | 11 lbs 7.4 oz | 100 | | | 120/1/60 | KES | GC | - | - | FURNISHED WITH ICE MAKER |

## KITCHEN HOOD SCHEDULE

| TAG | DESCRIPTION | MAX COOKING TEMP. | EXHAUST PLENUM | | | | | | PERFORATED SUPPLY PLENUMS | | | | | | | | | | NUMBER OF LIGHT FIXTURES | APPROXIMATE WEIGHT [lbs] | FURNISHED BY | INSTALLED BY | BASIS FOR DESIGN | | REMARKS |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | | AIRFLOW [CFM] | SP [in. W.C] | DUCT COLLARS | | | | SP [in. W.C.] | SUPPLY PLENUM LENGTH | SUPPLY PLENUM WIDTH | MAU PLENUM | | | | AC PLENUM | | | | | | | | MANUFACTURER | MODEL | |
| | | | | | NO. | WIDTH | LENGTH | LENGTH | WIDTH | | | | AIRFLOW [CFM] | DUCT COLLARS | | | AIRFLOW [CFM] | DUCT COLLARS | | | | | | | |
| | | | | | | | | | | | | | | NO. | WIDTH | LENGTH | | NO. | DIAMETER | | | | | |
| HD-1 | TYPE I CANOPY HOOD WITH PERFORATED MAU AND AC SUPPLY PLENUMS | 600°F | 3200 | 0.86 | 2 | 10" | 15" | 14' - 3" | 4' - 3" | 0.2 | 15' - 3" | 22" | 1950 | 3 | 10" | 28" | 800 | 7 | 8" | 10 | 1200 | HS | GC | CAPTIVE-AIRE | 5424 ND-2-ACPSP-F | MAT'L: 18 GA. TYPE 430 SS. PROVIDE WITH 16" TALL HE SS FILTERS, INTEGRAL UTILITY CABINET, ANSUL SYSTEM, DUCT COLLAR TEMPERATURE SENSOR, PREWIRE PACKAGE, SPARE FIRE SYSTEM DRY CONTACT, AND 4-POLE 20A CONTACTOR |

## ROOFTOP UNIT SCHEDULE

| TAG | DESCRIPTION | NOMINAL CAPACITY [TONS] | EER | AIRFLOW | | | NET COOLING CAPACITY | | | | | HEATING CAPACITY | | | # OF COMPRESSORS | # OF CIRCUITS | REFRIG. TYPE | REFRIG. CHARGE | APPROX. WEIGHT [lbs] | ELECTRICAL | | | FURNISHED BY | INSTALLED BY | BASIS FOR DESIGN | | REMARKS |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | | | TOTAL [CFM] | OA [CFM] | ESP [IN. W.C.] | TOTAL [MBH] | SENSIBLE [MBH] | EAT [DEG. F] | | COND. EAT [DEG. F] | INPUT [MBH] | OUTPUT [MBH] | EAT [DEG. F] | | | | | | MOCP | FLA | V/P/H | | | MANUFACTURER | MODEL | |
| | | | | | | | | | DB | WB | | | | | | | | | | | | | | | | |
| RTU-1 | KITCHEN ROOFTOP UNIT | 8.5 | 12 | 3400 | 400 | 0.8 | 104 | 59 | 75 | 65 | 88 | 120 | 96 | 60 | 2 | 2 | R-410A | 8.5/8.8 | 1350 | 60 A | 48.3 A | 208/3/60 | HES | GC | YORK | ZJ102 | FURNISHED WITH COMP. ENTHALPY ECON., BAROMETRIC RELIEF, RET. SMOKE DETECTOR W/ REMOTE KEYED ANNUNCIATOR/RESET, M.O.D., MERV-8 FILTERS, CURB, HAIL GUARD, TOOLLESS HINGED ACCESS PANELS, DISCONNECT, & UNIT-MOUNTED CONVENIENCE RECEPTACLE |
| RTU-2 | DINING ROOM ROOFTOP UNIT | 10 | 12 | 3500 | 1000 | 0.8 | 123 | 78 | 78 | 67 | 88 | 240 | 192 | 48 | 2 | 2 | R-410A | 7.9/7.9 | 1350 | 50 A | 44.9 A | 208/3/60 | HES | GC | YORK | ZJ120 | FURNISHED WITH COMP. ENTHALPY ECON., BAROMETRIC RELIEF, RET. SMOKE DETECTOR W/ REMOTE KEYED ANNUNCIATOR/RESET, M.O.D., MERV-8 FILTERS, CURB, HAIL GUARD, TOOLLESS HINGED ACCESS PANELS, DISCONNECT, & UNIT-MOUNTED CONVENIENCE RECEPTACLE |

## CONTROL FUNCTIONS

A. THE MAIN COOKING EXHAUST FAN AND MAKE-UP AIR UNIT SHALL BE INTERLOCKED TO OPERATE TOGETHER. THIS CONTROL CIRCUIT IS ACTIVATED BY A SWITCH AND INCLUDES A FIRE PROTECTION OVERRIDE.
B. THE TEMPERATURE IN EACH ZONE IS CONTROLLED BY SPACE TEMPERATURE SENSORS CONNECTED TO THE THERMOSTATS LOCATED IN THE OFFICE. ALL ZONES SHALL OPERATE WITH CONTINUOUS FAN OPERATION DURING OCCUPIED TIMES AND INTERMITTENTLY AS NEEDED TO MAINTAIN SET POINTS DURING UNOCCUPIED TIMES. OUTSIDE AIR DAMPERS SHALL BE OPEN CONTINUOUSLY WHEN EITHER IN OCCUPIED MODE OR WHEN THE HOOD SYSTEM IS ON AND SHALL BE CLOSED DURING UNOCCUPIED PERIODS.
C. THE THERMOSTATS SHALL DETERMINE OCCUPIED/UNOCCUPIED STATUS BASED ON THE SCHEDULE IN THE ENERGY MANAGEMENT SYSTEM.

## AIR BALANCE SCHEDULE

| Tag | Supply Flow [CFM] | Return Flow [CFM] | Exhaust Flow [CFM] | Subtotal [CFM] |
|---|---|---|---|---|
| EF-1 | 0 | 0 | 3200 | -3200 |
| EF-2 | 0 | 0 | 150 | -150 |
| MAU-1 | 1950 | 0 | 0 | 1950 |
| RTU-1 | 3400 | 3000 | 0 | 400 |
| RTU-2 | 3500 | 2500 | 0 | 1000 |
| Net Pressurization [CFM] | | | | 0 |


Consultant:
NATIONAL ENGINEERING
4635 Trueman Blvd. Suite 250
Hilliard, Ohio 43026
Phone: (614) 751-9610
Fax: (614) 552-5240
Contact: Cliff Kigar
(614) 328-2033
ckigar@nationalengineering.com


STATE OF OHIO
RICHARD T JONES
No. E-52450
REGISTERED
PROFESSIONAL ENGINEER

Signed On
06/03/202210:39:10 AM


COPYRIGHT 2022
THIS DRAWING IS AN INSTRUMENT OF SERVICE AND AS SUCH REMAINS THE PROPERTY OF CHIPOTLE MEXICAN GRILL, INC.. PERMISSION FOR USE OF THIS DOCUMENT IS LIMITED AND CAN BE EXTENDED ONLY BY WRITTEN AGREEMENT WITH CHIPOTLE MEXICAN GRILL, INC..



CHIPOTLE MEXICAN GRILL, INC.
PO BOX 182566
COLUMBUS, OH 43218-2566
TELEPHONE: (614) 318-2400
INTERNET: WWW.CHIPOTLE.COM


STORE NO.: 4538
EAST LIVERPOOL
16300 DRESDEN AVE.
EAST LIVERPOOL, OH 43920

Issue Record:
06-03-22 PERMIT SET

Revisions:

Drawn: CJK
Checked: JEI/CJK

Project No.
2201090

Contents:
HVAC SCHEDULES

M600