

All HVAC, Hoods, and General purpose fans are 100% installed, all duct is complete Yes

IN ORDER FOR US TO ARRIVE ON SITE, THE FOLLOWING ITEMS MUST BE COMPLETE 3 WORKING DAYS PRIOR TO OUR ARRIVAL (THERE WILL BE A SCHEDULING CANCELLATION CHARGE IF CANCELLED AT THIS TIME

RTU Economizers are installed and operating Yes

Thermostat's and sensors are 100% wired and functional for both occupied and unoccupied periods Yes

RTU and General Purpose fan diffusers have been 100% installed Yes

RTU startup's are complete Yes

Hood Fire Suppression Test is scheduled to be competed prior to our arrival (list the date of the hood's fire suppression city test)Yes 1/26

Note: If we arrive on site and items above are not complete or not made ready without delay of our tech, there will be additional cancellation or delay of services charges applied

Notes/Comments :