




10-09-23 PERRY'S - RICHMOND, VA (CX, TAB)

CheckList Information

Name : Patio Heaters **Status :** Not Completed
Assigned Organization : National TAB **Asset :**
Requesting Organization : National TAB


CheckList Item Details



Number of Patio Heaters 10

Location of heaters are installed and controlled as designated Yes

Comment Heater switch 1 (3 heaters), Heater switch 2 (3 heaters), Heater switch 3 (2 heaters), Heater switch 4 (2 heaters)



patio_heater_layout.jpg

Patio heater control method Pass

Comment On / Off heater switch with timers that are adjustable 15min, 30min, 60min, 2 hours, 4 hours.



patio_heater_controls.jpg

S00

Pass

Comment

To operate any zone, set the timer clock for the length of time heating is desired. Adjust the heater switch to its desired temperature. Ensure the power on light is illuminated.

When turned on Heaters energize according to heaters allocated to each switch and vary in temperature based on temp setting

Pass

Comment

Timer clock tested to de-energize at end of timer cycle

Pass

Comment

Notes/Comments :