



City BBQ (Johnson City, TN)

Project Issue Information

Issue Name : No OA on RTU's
Description : None of the RTU's have OA intakes. OA could not be balanced.
Created By : National TAB **Assigned To :** National TAB - Dan Hertenstein
Status : Open
Priority : Urgent **Asset Tag :**
Originated Date : 12/17/2025 - Christian Moller - National TAB

Project Issue File Details



12/17/2025



12/17/2025



12/17/2025