

PlanGrid Task Report - Nov 4, 2024

Prepared by Stephen Tassinaro

Nov 4, 2024

Description

3 tasks in this report.

Contents

#314 [UNIT 501] [NEW] Equipment low voltage diagrams.....	2
#308 [UNIT 505] [NEW] Equipment wiring portals.	3
#306 [UNIT 522] [NEW] AC air filters.	4

L05416_RELO Hull Street at Brandermill FSU...

Hull Street and Brandermill, Richmond, Virginia

L2220005416

#314 [UNIT 501] [NEW] Equipment low voltage diagrams

Status

Open

Start Date

Oct 24, 2024

Sheet

M-701

Type

Planned Work

Created


Nov 4, 2024 7:07 AM
stephent@nationaltab.com

Description

Equipment missing
laminated copy of controls
detail low voltage wiring
diagrams.

Last Updated

Nov 4, 2024 7:07 AM



L05416_RELO Hull Street at Brandermill FSU...

Hull Street and Brandermill, Richmond, Virginia

L2220005416

#308 [UNIT 505] [NEW] Equipment wiring portals.

Status

Open

Assignees

robbie.hooker@getsterling.com

Type

Planned Work

Watchers

robbie.hooker@getsterling.com

Description

Equipment wiring portal missing or not utilized correctly. Portal cover should be secured and all wiring should be routed via portal cover with conduit connectors or low voltage wiring grommets to protect wiring from shorts. RTU-1 low voltage wiring needs grommet at penetration.

Start Date

Oct 23, 2024

Created

Oct 23, 2024 2:58 PM
stephent@nationaltab.com

Last Updated

Oct 25, 2024 8:06 AM

Photos

L05416_RELO Hull Street at Brandermill FSU...

Hull Street and Brandermill, Richmond, Virginia

L2220005416



IMG_4187

Stephen Tassinaro

Oct 23, 2024 3:02 PM

#306 [UNIT 522] [NEW] AC air filters.

Status

Open

Type

Planned Work

Description

Missing extra set per specification.

Assignees

robbie.hooker@getsterling.com

Watchers

robbie.hooker@getsterling.com

Start Date


Oct 23, 2024

Created

Oct 23, 2024 2:58 PM

Sheet

M-001



L05416_RELO Hull Street at Brandermill FSU...

Hull Street and Brandermill, Richmond, Virginia

L2220005416

stephent@nationaltab.com

Last Updated

Oct 25, 2024 8:06 AM
