



# National TAB

Project: Legent Hospital (Tomball, TX)

## VAV - Single Duct

### RTU-2-1/222

Asset									
Asset Name	Type	Inlet Size	Design Max CFM	Max CFM	Design Min CFM	Min CFM	Design Heat CFM	Heat CFM	Ak (max)
RVAV-2-1	RVAV	14	1870	1865	1870	1865	-	-	1.38
RVAV-2-2	RVAV	14	1820	1826	1820	1826	-	-	1.08
RVAV-2-3	RVAV	14	1815	1810	1815	1810	-	-	1.36
RVAV-2-4	RVAV	14	1590	1584	1590	1584	-	-	1.50
RVAV-2-5	RVAV	10	785	728	785	728	-	-	1.23
RVAV-2-6	RVAV	10	750	754	750	754	-	-	1.22
RVAV-2-7	RVAV	10	790	783	790	783	-	-	0.73
RVAV-2-8	RVAV	10	500	497	500	497	-	-	0.72
RVAV-2-9	RVAV	14	1980	1996	440	448	-	-	1.41
VAV-2-1	VAV	14	2070	2087	2070	2087	2070	2112	0.88
VAV-2-2	VAV	14	2020	2023	2020	2023	2020	2022	0.80
VAV-2-3	VAV	14	2015	2124	2015	2124	2015	2124	0.89
VAV-2-4	VAV	14	1790	1805	1790	1805	1790	1760	0.98
VAV-2-5	VAV	8	410	409	325	329	325	329	1.23
VAV-2-6	VAV	8	570	569	525	528	525	526	1.29
VAV-2-7	VAV	14	1530	1514	1530	1514	1170	1172	1.24
VAV-2-8	VAV	10	890	892	890	892	710	714	1.59
VAV-2-9	VAV	6	370	375	195	192	195	197	0.94
VAV-2-10	VAV	10	705	693	140	148	400	385	1.21
VAV-2-11	VAV	6	210	211	210	211	210	214	1.02
VAV-2-19	VAV	14	2180	2136	440	452	800	782	0.95

### RTU-2-2/201

Asset								
Asset Name	Type	Inlet Size	Design Max CFM	Max CFM	Design Min CFM	Min CFM	Design Heat CFM	
VAV-2-12	VAV	10	685	689	500	504		0.93
VAV-2-13	VAV	10	910	904	220	227		0.82
VAV-2-14	VAV	10	835	831	735	730		1.16
VAV-2-15	VAV	6	320	317	250	256		0.53
VAV-2-16	VAV	6	210	212	210	212		1.06
VAV-2-17	VAV	8	405	409	250	254		1.02
VAV-2-18	VAV	10	730	738	420	417		1.01

Completed By: Wesley John on 02/04/2024