

Report By:

**National TAB
1329 E. KEMPER ROAD
SUITE 4210
CINCINNATI, OH 45246**

NATIONAL

TAB

Comfort. Under control.

**Report: PRELIM REPORT
Function: Test, Adjust, & Balance
Date: 02/14/2023**

PROJECT

Chuck E Cheese (Columbus, OH)

3886 Morse Rd

Columbus, OH

Client

Parkway Construction

1000 Civic Circle

Lewisville, TX 75067

National TAB

Project: Chuck E Cheese (Columbus, OH)

Table Of Contents

Section	Page #
AHU/RTU	3
FAN - Exhaust	17
Kitchen Hood Type I	24
Kitchen Hood Type II	25

National TAB

Project: Chuck E Cheese (Columbus, OH)

System/Unit: AHU/RTU



Comfort. Under control.

Asset: RTU-1

AREA: KITCHEN

Unit Data		
	Design	Actual
MFG	NA	LENNOX
Serial Num	-	5617M01179
Model Num	NA	LGH120H4BH3G
Configuration	VERTICAL	VERTICAL
Num OA Filters 1	-	2
OA Filter Size 1	-	25X16
Num PreFilter 1	-	4
PreFilter Size 1	-	20X25X2

Test Data		
	Design	Actual
SF CFM	3900	3949
SF RPM	-	931
RA CFM	2652	2819
OA CFM	1248	1130
RL Voltage	-	492/490/489
RL Amperage	-	3.84/3.85/4.14
OA Damper Position	-	38%
Brake Horse Power	-	2.93

Motor Data		
	Design	Actual
Motor MFG	-	INTERLINK
Frame	-	56HZ
Horsepower	3.0	3
Motor Rpm	-	1750
Phase	3	3
Rated Voltage	480	460
Rated Amperage	-	4.0
Service Factor	-	1.15

Performance Data		
	Design	Actual
MA Plenum SP	-	-0.48"
Fan Suction SP	-	-0.83"
Fan Discharge SP	-	0.82"
Total ESP	-	1.30"
Fan Total SP	-	1.65"

Drive Data		
	Design	Actual
Motor Sheave Size	-	MVL40
Motor Bore Size	-	0.875
Motor Sheave SetPt	-	0 TURNS OUT
Fan Sheave Size	-	7"
Fan Sheave Bore	-	1"
Belt CL Distance	-	22.5"
Num of Belts	-	1
Belt Size	-	AX58

Completed By: Tyler Youells

Notes:

National TAB

Project: Chuck E Cheese (Columbus, OH)

AHU/RTU



Comfort. Under control.

Diffuser Supply (GRD)

RTU-1/KITCHEN

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
1-1	KITCHEN	G	8	150	95	158	105.3
1-2	KITCHEN	M	10	200	52	215	107.5
1-3	KITCHEN	H	6X6X8	100	175	109	109.0
1-4	KITCHEN	H	6X6X8	100	109	97	97.0
1-5	SKILLS	F	10	350	211	385	110.0
1-6	KITCHEN	G	8	150	158	154	102.7
1-7	KITCHEN	G	8	200	180	197	98.5
1-8	KITCHEN	E	12	500	361	478	95.6
1-9	KITCHEN	G	8	200	296	190	95.0
1-10	KITCHEN	E	12	500	335	479	95.8
1-11	KITCHEN	G	8	200	164	197	98.5
1-12	KITCHEN	E	12	500	304	498	99.6
1-13	KITCHEN	F	10	350	343	364	104.0
1-14	KITCHEN	F	10	300	282	327	109.0
1-15	KITCHEN	H	6X6X8	100	112	101	101.0

Diffuser Ret/Exh (GRD)

RTU-1/KITCHEN

Asset								
Asset Name	Type	Size	DESIGN CFM	AK	CFM(1)	CFM(2)	FINAL CFM	% to design
R1-1	J	46X22	1326	1	1524		1429	107.8
R1-2	J	46X22	1326	1	1439		1390	104.8

Completed By: Michael Gabbert on

National TAB

Project: Chuck E Cheese (Columbus, OH)

System/Unit: AHU/RTU



Comfort. Under control.

Asset: RTU-2

AREA:SKILLS

Unit Data		
	Design	Actual
MFG	NA	LENNOX
Serial Num	-	5617M04704
Model Num	NA	LGH120H4BH3G
Configuration	VERTICAL	VERTICAL
Num OA Filters 1	-	2
OA Filter Size 1	-	25 X 16
Num PreFilter 1	-	4
PreFilter Size 1	-	20X25X2

Test Data		
	Design	Actual
SF CFM	4000	4096
SF RPM	-	938
RA CFM	2720	2903
OA CFM	1280	1193
RL Voltage	-	490/489/491
RL Amperage	-	3.71/3.63/3.79
OA Damper Position	-	48%
Brake Horse Power	-	2.78

Motor Data		
	Design	Actual
Motor MFG	-	INTERLINK
Frame	-	56HZ
Horsepower	3.0	3
Motor Rpm	-	1750
Phase	3	3
Rated Voltage	480	460
Rated Amperage	-	4.0
Service Factor	-	1.15

Performance Data		
	Design	Actual
MA Plenum SP	-	-0.50"
Fan Suction SP	-	-0.78"
Fan Discharge SP	-	0.95"
Total ESP	0.8	1.45"
Fan Total SP	-	1.73"

Drive Data		
	Design	Actual
Motor Sheave Size	-	1VL40
Motor Bore Size	-	0.875"
Motor Sheave SetPt	-	0.875"
Fan Sheave Size	-	7"
Fan Sheave Bore	-	1"
Belt CL Distance	-	22.5
Num of Belts	-	1
Belt Size	-	AX58

Completed By: Tyler Youells

Notes:

National TAB

Project: Chuck E Cheese (Columbus, OH)

AHU/RTU



Comfort. Under control.

Diffuser Supply (GRD)

RTU-2/SKILLS

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
2-1	SKILLS	E	12	500	382	473	94.6
2-2	SKILLS	E	12	500	358	534	106.8
2-3	SKILLS	E	12	500	448	490	98.0
2-4	SKILLS	E	12	500	348	541	108.2
2-5	SKILLS	E	12	500	410	488	97.6
2-6	SKILLS	E	12	500	410	545	109.0
2-7	SKILLS	E	12	500	391	495	99.0
2-8	SKILLS	E	12	500	362	530	106.0

Diffuser Ret/Exh (GRD)

RTU-2/SKILLS

Asset								
Asset Name	Type	Size	DESIGN CFM	AK	CFM(1)	CFM(2)	FINAL CFM	% to design
R2-1	K	46X22(2)	2720	1	3210		2903	106.7

Completed By: Michael Gabbert on

National TAB

Project: Chuck E Cheese (Columbus, OH)

System/Unit: AHU/RTU



Comfort. Under control.

Asset: RTU-3

AREA:KIDDIE

Unit Data		
	Design	Actual
MFG	NA	LENNOX
Serial Num	-	5617F06682
Model Num	NA	LGH120H4BH3G
Configuration	VERTICAL	VERTICAL
Num OA Filters 1	-	2
OA Filter Size 1	-	25X16
Num PreFilter 1	-	4
PreFilter Size 1	-	20X25X2

Test Data		
	Design	Actual
SF CFM	2320	2244
SF RPM	-	673
RA CFM	1578	1524
OA CFM	742	720
RL Voltage	-	490/490/489
RL Amperage	-	3.15/2.85/2.85
OA Damper Position	-	60%
Brake Horse Power	-	2.21

Motor Data		
	Design	Actual
Motor MFG	-	INTERLINK
Frame	-	56HZ
Horsepower	3.0	3.0
Motor Rpm	-	1750
Phase	3	3
Rated Voltage	480	460
Rated Amperage	-	4.0
Service Factor	-	1.15

Performance Data		
	Design	Actual
MA Plenum SP	-	-0.11"
Fan Suction SP	-	-0.25"
Fan Discharge SP	-	0.63"
Total ESP	0.8	0.74"
Fan Total SP	-	0.88"

Drive Data		
	Design	Actual
Motor Sheave Size	-	1VL40
Motor Bore Size	-	0.875"
Motor Sheave SetPt	-	5 TURNS OUT
Fan Sheave Size	-	7"
Fan Sheave Bore	-	1"
Belt CL Distance	-	22.5"
Num of Belts	-	1
Belt Size	-	AX58

Completed By: Tyler Youells

Notes:

National TAB

Project: Chuck E Cheese (Columbus, OH)

AHU/RTU



Comfort. Under control.

Diffuser Supply (GRD)

RTU-3/KIDDIE

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
3-1	HALL	G	8	200	389	196	98.0
3-2	TOILET	E	12	390	449	380	97.4
3-3	TOILET	E	12	390	490	382	97.9
3-4	HALL	G	8	100	71	102	102.0
3-5	TOILET	G	8	200	232	182	91.0
3-6	CHUCK E CHANGE	G	8	200	294	202	101.0
3-7	KIDDIE	E	12	420	451	410	97.6
3-8	KIDDIE	E	12	420	373	390	92.9

Diffuser Ret/Exh (GRD)

RTU-3/KIDDIE

Asset								
Asset Name	Type	Size	DESIGN CFM	AK	CFM(1)	CFM(2)	FINAL CFM	% to design
R3-1	K	46X22(2)	1578	1	1578		1524	96.6

Completed By: Michael Gabbert on

National TAB

Project: Chuck E Cheese (Columbus, OH)
System/Unit: AHU/RTU



Comfort. Under control.

Asset: RTU-4

AREA: BIRTHDAY

Unit Data		
	Design	Actual
MFG	NA	LENNOX
Serial Num	-	5617C11342
Model Num	NA	LGH120H4MS3G
Configuration	VERTICAL	VERTICAL
Num OA Filters 1	-	2
OA Filter Size 1	-	25X16
Num PreFilter 1	-	4
PreFilter Size 1	-	25X20

Test Data		
	Design	Actual
SF CFM	4000	3998
SF RPM	-	949
RA CFM	2720	2694
OA CFM	1280	1304
RL Voltage	-	482/489/489
RL Amperage	-	3.63/3.60/3.63
OA Damper Position	-	45%
Brake Horse Power	-	2.7

Motor Data		
	Design	Actual
Motor MFG	-	INTERLINK
Frame	-	56HZ
Horsepower	3.0	3
Motor Rpm	-	1750
Phase	3	3
Rated Voltage	480	460
Rated Amperage	-	4.0
Service Factor	-	1.15

Performance Data		
	Design	Actual
MA Plenum SP	-	-0.55"
Fan Suction SP	-	-0.87"
Fan Discharge SP	-	0.89"
Total ESP	0.8	1.44"
Fan Total SP	-	1.76"

Drive Data		
	Design	Actual
Motor Sheave Size	-	4"
Motor Bore Size	-	0.875"
Motor Sheave SetPt	-	0 TURNS OUT
Fan Sheave Size	-	7"
Fan Sheave Bore	-	1"
Belt CL Distance	-	21.5"
Num of Belts	-	1
Belt Size	-	AX58

Completed By: Tyler Youells

Notes:

National TAB

Project: Chuck E Cheese (Columbus, OH)

AHU/RTU



Comfort. Under control.

Diffuser Supply (GRD)

RTU-4/BIRTHDAY

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
4-1	BIRTHDAY	F	10	360	325	343	95.3
4-2	BIRTHDAY	F	10	360	341	334	92.8
4-3	BIRTHDAY	F	10	300	235	306	102.0
4-4	BIRTHDAY	F	10	300	247	328	109.3
4-5	BIRTHDAY	F	10	300	288	286	95.3
4-6	BIRTHDAY	F	10	300	325	275	91.7
4-7	BIRTHDAY	F	10	380	337	365	96.1
4-8	BIRTHDAY	F	10	360	325	375	104.2
4-9	BIRTHDAY	F	10	300	323	313	104.3
4-10	BIRTHDAY	F	10	380	303	373	98.2
4-11	BIRTHDAY	F	10	300	185	318	106.0
4-12	BIRTHDAY	F	10	360	266	382	106.1

Diffuser Ret/Exh (GRD)

RTU-4/BIRTHDAY

Asset								
Asset Name	Type	Size	DESIGN CFM	AK	CFM(1)	CFM(2)	FINAL CFM	% to design
R4-1	K	46X22(2)	2720	1	3091		2694	99.0

Completed By: Michael Gabbert on

National TAB

Project: Chuck E Cheese (Columbus, OH)

System/Unit: AHU/RTU



Comfort. Under control.

Asset: RTU-5

AREA:HALLWAY

Unit Data		
	Design	Actual
MFG	NA	LENNOX
Serial Num	-	5617A03662
Model Num	NA	LGH072H4BU4G
Configuration	VERTICAL	VERTICAL
Num OA Filters 1	-	1
OA Filter Size 1	-	33X15
Num PreFilter 1	-	4
PreFilter Size 1	-	20X20X2

Test Data		
	Design	Actual
SF CFM	2200	2160
SF RPM	-	943
RA CFM	1496	1451
OA CFM	704	709
RL Voltage	-	492/490/489
RL Amperage	-	2.92/2.89/2.93
OA Damper Position	-	33%
Brake Horse Power	-	2.92

Motor Data		
	Design	Actual
Motor MFG	-	Interlink
Frame	-	56HZ
Horsepower	3.0	2
Motor Rpm	-	1755
Phase	3	3
Rated Voltage	480	460
Rated Amperage	-	2.9
Service Factor	-	1.15

Performance Data		
	Design	Actual
MA Plenum SP	-	-0.29"
Fan Suction SP	-	-0.77"
Fan Discharge SP	-	0.77"
Total ESP	0.8	1.06"
Fan Total SP	-	1.54"

Drive Data		
	Design	Actual
Motor Sheave Size	-	1VL40
Motor Bore Size	-	0.875"
Motor Sheave SetPt	-	2 OUT
Fan Sheave Size	-	5.5"
Fan Sheave Bore	-	1"
Belt CL Distance	-	18"
Num of Belts	-	1
Belt Size	-	A50

Completed By: Tyler Youells

Notes:

National TAB

Project: Chuck E Cheese (Columbus, OH)

AHU/RTU



Comfort. Under control.

Diffuser Supply (GRD)

RTU-5/HALLWAY

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
5-1	REPAIR	E	12	200	362	215	107.5
5-2	REPAIR	E	12	400	293	410	102.5
5-3	BIRTHDAY	F	8	400	160	387	96.8
5-4	LAUNDRY	G	10	200	261	205	102.5
5-5	HALLWAY	O	10	300	166	279	93.0
5-6	HALLWAY	O	10	300	215	285	95.0
5-7	HALLWAY	E	12	400	330	379	94.8

Completed By: Michael Gabbert on

National TAB

Project: Chuck E Cheese (Columbus, OH)

System/Unit: AHU/RTU



Comfort. Under control.

Asset: RTU-6

AREA: BIRTHDAY

Unit Data		
	Design	Actual
MFG	NA	TRANE
Serial Num	-	223910443L
Model Num	NA	YSC120H4RLA290
Configuration	VERTICAL	VERTICAL
Num OA Filters 1	-	1
OA Filter Size 1	-	27X17
Num PreFilter 1	-	4
PreFilter Size 1	-	20X25X2

Test Data		
	Design	Actual
SF CFM	4200	4464
SF RPM	-	2.02V
RA CFM	2856	3104
OA CFM	1344	1360
RL Voltage	-	485/491/489
RL Amperage	-	2.03/2.01/2.02
OA Damper Position	-	4.95V
Brake Horse Power	-	1.53

Motor Data		
	Design	Actual
Horsepower	3.0	2.75
Phase	3	3
Rated Voltage	480	460
Rated Amperage	-	3.6

Performance Data		
	Design	Actual
MA Plenum SP	-	-0.57"
Fan Suction SP	-	-0.80"
Fan Discharge SP	-	0.55"
Total ESP	0.8	1.12
Fan Total SP	-	1.35"

Drive Data		
	Design	Actual

Completed By: Tyler Youells

Notes:

National TAB

Project: Chuck E Cheese (Columbus, OH)

AHU/RTU



Comfort. Under control.

Diffuser Supply (GRD)

RTU-6/BIRTHDAY

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
6-1	BIRTHDAY	E	12	420	190	409	97.4
6-2	BIRTHDAY	E	12	420	320	431	102.6
6-3	BIRTHDAY	E	12	420	335	421	100.2
6-4	BIRTHDAY	E	12	420	341	407	96.9
6-5	BIRTHDAY	E	12	420	330	416	99.0
6-6	BIRTHDAY	E	12	420	368	420	100.0
6-7	BIRTHDAY	E	12	420	373	425	101.2
6-8	BIRTHDAY	E	12	420	352	399	95.0
6-9	BIRTHDAY	E	12	420	437	432	102.9
6-10	BIRTHDAY	E	12	420	321	404	96.2

Diffuser Ret/Exh (GRD)

RTU-6/BIRTHDAY

Asset								
Asset Name	Type	Size	DESIGN CFM	AK	CFM(1)	CFM(2)	FINAL CFM	% to design
R6-1	K	46X22(2)	2856	1	3249		3104	108.7

Completed By: Michael Gabbert on

National TAB

Project: Chuck E Cheese (Columbus, OH)
System/Unit: AHU/RTU



Comfort. Under control.

Asset: RTU-7

AREA:SKILLS

Unit Data		
	Design	Actual
MFG	NA	TRANE
Serial Num	-	224010296L
Model Num	NA	YSC120H4RLA29
Configuration	VERTICAL	VERTICAL
Num OA Filters 1	-	1
OA Filter Size 1	-	37X17
Num PreFilter 1	-	4
PreFilter Size 1	-	20X25X2

Test Data		
	Design	Actual
SF CFM	4200	4160
SF RPM	-	1.954V
RA CFM	2856	2758
OA CFM	1344	1402
RL Voltage	-	492/489/492
RL Amperage	-	1.87/1.79/1.86
OA Damper Position	-	5.46V
Brake Horse Power	-	1.41

Motor Data		
	Design	Actual
Horsepower	3.0	2.75
Phase	3	3
Rated Voltage	480	460
Rated Amperage	-	3.6
Service Factor	-	1

Performance Data		
	Design	Actual
MA Plenum SP	-	-0.37"
Fan Suction SP	-	-0.56"
Fan Discharge SP	-	0.45"
Total ESP	0.8	0.82"
Fan Total SP	-	1.01"

Drive Data		
	Design	Actual

Completed By: Tyler Youells

Notes:

National TAB

Project: Chuck E Cheese (Columbus, OH)

AHU/RTU



Comfort. Under control.

Diffuser Supply (GRD)

RTU-7/SKILLS

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
7-1	SKILLS	F	10	400	320	424	106.0
7-2	SKILLS	F	10	400	353	437	109.3
7-3	SKILLS	F	10	400	280	386	96.5
7-4	SKILLS	F	10	400	454	363	90.8
7-5	SKILLS	F	10	400	356	370	92.5
7-6	SKILLS	F	10	400	347	364	91.0
7-7	SKILLS	G	8	200	222	216	108.0
7-8	SKILLS	F	10	400	276	433	108.3
7-9	SKILLS	F	10	400	325	385	96.3
7-10	SKILLS	G	8	200	203	202	101.0
7-11	SKILLS	G	8	200	214	201	100.5
7-12	SKILLS	G	8	200	156	197	98.5
7-13	SKILLS	G	8	200	220	182	91.0

Diffuser Ret/Exh (GRD)

RTU-7/SKILLS

Asset								
Asset Name	Type	Size	DESIGN CFM	AK	CFM(1)	CFM(2)	FINAL CFM	% to design
R7-1	K	46X22(2)	2856	1	2997		2758	96.6

Completed By: Michael Gabbert on

National TAB

Project: Chuck E Cheese (Columbus, OH)
System/Unit: FAN - Exhaust



Comfort. Under control.

Asset: EF-1

AREA:PIZZA HOOD

Unit Data		
	Design	Actual
MFG	GREENHECK	ACCUREX
Model Num	G-080-VG	XRUD-140-10-VG-1-26-G
Serial Num	-	21181980
Type	KEF CRE	UPBLAST

Test Data		
	Design	Actual
CFM	2000	2187
RL Voltage	-	120.5
RL Amperage	-	11.48
Total ESP	0.50	1.18"

Motor Data		
	Design	Actual
Motor MFG	-	VARIGREEN
Frame	-	NL
Horsepower	0.75	1
Motor Rpm	-	1750
Phase	1	1
Voltage (rated)	120	115
Amperage (rated)	-	11.5
Service Factor	-	1

Completed By: Tyler Youells

Notes:

National TAB

Project: Chuck E Cheese (Columbus, OH)
System/Unit: FAN - Exhaust



Comfort. Under control.

Asset: EF-2

AREA: DISHWASH

Unit Data		
	Design	Actual
MFG	GREENHECK	ACCUREX
Model Num	G-080-VG	XCUE-095-6-VG-1-19-X
Serial Num	-	21182149
Type	KEF CRE	CRE

Test Data		
	Design	Actual
CFM	400	409
RL Voltage	-	1.79
RL Amperage	-	1.9
Total ESP	0.50	0.29"

Motor Data		
	Design	Actual
Motor MFG	-	VARIGREEN
Frame	-	NL
Horsepower	0.25	0.5
Motor Rpm	-	1750
Phase	1	1
Voltage (rated)	120	115
Amperage (rated)	-	2.3
Service Factor	-	1

Completed By: Tyler Youells

Notes:

National TAB

Project: Chuck E Cheese (Columbus, OH)
System/Unit: FAN - Exhaust



Comfort. Under control.

Asset: EF-3

AREA:TOILET

Unit Data		
	Design	Actual
MFG	GREENHECK	ACCUREX
Model Num	G-080-VG	XCUE-090-VG-1-19-X
Serial Num	-	21182303
Type	CRE	CRE

Test Data		
	Design	Actual
CFM	800	830
RL Voltage	-	120.6
RL Amperage	-	0.94
Total ESP	0.50	0.26"

Motor Data		
	Design	Actual
Motor MFG	-	VARIGREEN
Frame	-	NL
Horsepower	0.167	0.10
Motor Rpm	-	1750
Phase	1	1
Voltage (rated)	120	115
Amperage (rated)	-	1.5
Service Factor	-	1

Completed By: Tyler Youells

Notes:

National TAB

Project: Chuck E Cheese (Columbus, OH)

FAN - Exhaust



Comfort. Under control.

Diffuser Ret/Exh (GRD)

EF-3/TOILET

Asset								
Asset Name	Type	Size	DESIGN CFM	AK	CFM(1)	CFM(2)	FINAL CFM	% to design
E3-1	L	22X22	400	1	500		421	105.3
E3-2	L	22X22	400	1	459		409	102.3

Completed By: Michael Gabbert on

National TAB

Project: Chuck E Cheese (Columbus, OH)
System/Unit: FAN - Exhaust



Comfort. Under control.

Asset: EF-4

AREA:UTILITY

Unit Data		
	Design	Actual
MFG	GREENHECK	ACCUREX
Model Num	G-080-VG	XCUE-070-VG-1-17-X
Serial Num	-	21182367
Type	CRE	CRE

Test Data		
	Design	Actual
CFM	200	192
RL Voltage	-	120.4
RL Amperage	-	0.71
Total ESP	0.50	0.25"

Motor Data		
	Design	Actual
Motor MFG	-	VARIGREEN
Frame	-	NL
Horsepower	0.05	0.067
Motor Rpm	-	1750
Phase	1	1
Voltage (rated)	120	115
Amperage (rated)	-	1.3
Service Factor	-	1

Completed By: Tyler Youells

Notes:

National TAB

Project: Chuck E Cheese (Columbus, OH)

FAN - Exhaust



Comfort. Under control.

Diffuser Ret/Exh (GRD)

EF-4/UTILITY

Asset								
Asset Name	Type	Size	DESIGN CFM	AK	CFM(1)	CFM(2)	FINAL CFM	% to design
E4-1	L	22X22	200	1	140		192	96.0

Completed By: Michael Gabbert on

National TAB

Project: Chuck E Cheese (Columbus, OH)
System/Unit: FAN - Exhaust



Comfort. Under control.

Asset: EF-5

AREA:CO2

Unit Data		
	Design	Actual
MFG	GREENHECK	ACCUREX
Model Num	G-080-VG	XCUE-070-Y6-1-17-X
Serial Num	-	21182399
Type	CRE	CRE

Test Data		
	Design	Actual
CFM	200	208
RL Voltage	-	120.1
RL Amperage	-	1.1
Total ESP	0.50	0.21"

Motor Data		
	Design	Actual
Motor MFG	-	VARIGREEN
Frame	-	NL
Horsepower	0.05	0.067
Motor Rpm	-	1750
Phase	1	1
Voltage (rated)	120	115
Amperage (rated)	-	1.3
Service Factor	-	1

Completed By: Tyler Youells

Notes:

National TAB

Project: Chuck E Cheese (Columbus, OH)

System/Unit: Kitchen Hood Type I



Comfort. Under control.

Asset: HOOD-2

AREA: DISHWASH

Unit Data		
	Design	Actual
MFG	CAPTIVEAIRE	ACCUREX
Model Num	4824 VHB-G	XD14200S
Job / Serial Num	-	21181189
Type	TYPE II CANOPY	TYPE II CANOPY
Hood length	48	42
Hood Width	-	42.5

Test Data Exhaust		
	Design	Actual
CFM	400	409

Cooking Equipment		
	Design	Actual

Completed By: Tyler Youells

Notes:

National TAB

Project: Chuck E Cheese (Columbus, OH)

System/Unit: Kitchen Hood Type II



Comfort. Under control.

Asset: HOOD-1

AREA:PIZZA

Unit Data		
	Design	Actual
MFG	CAPTIVEAIRE	ACCUREX
Model Num	7224 ND-2	XXEW9600S
Serial Num	-	21181190
Type	TYPE I CANOPY	TYPE I CANOPY
Hood length	96	96
Hood Width	-	72

Test Data		
	Design	Actual
Exhaust CFM	2000	2187

Completed By: Tyler Youells

Notes: