



### 08-04-25 BOJANGLES 1246 MORROW, GA TAB SURVEY

#### CheckList Information

**Name :** EF-1 Inspection                      **Status :** Not Completed

**Assigned Organization :** National TAB                      **Asset :**

**Requesting Organization :** National TAB

**Created Date :** 08/01/2025 - Will Turnbough - National TAB

#### CheckList Item Details

**EF Inspection:**

Area served

**Comment:**

Measure length and width of curb.

**Comment:**

No unusual noise or vibration?

**Comment:**

List any visual damage and take additional pictures if needed.

**Comment:**

If direct drive fan, is the speed controller or VFD functional?

**Comment:**

If belt driven are the pulleys in good condition and not rusted?

**Comment:**

Is belt tight?

**Comment:**

**Pictures**

---

Exterior of fan from multiple angles

---

**Comment:**

---

Inside of motor compartment

---

**Comment:**

---