



**FLOOR PLAN - HVAC**  
 1/16" = 1'-0"

**HVAC PLAN KEYED NOTES**

- (1) LOCATION OF FACTORY DUCT MOUNTED SMOKE DETECTOR IN RETURN OF RTU. PROVIDE ROUTE EXHAUSTOR OUTDOOR AIR INTAKES AND 5'-0" FROM CHASSET WALLS. ALL GREASE DUCT IS TO BE INSTALLED WITH DUCT WHP AS DETAIL AND PER THE MANUFACTURER'S REQUIREMENTS FOR 0" CLEARANCE TO COMBUSTIBLES.
- (2) TRANSITION AND CONNECT 10" DIAMETER GREASE DUCT TO EXHAUST HOOD. ROUTE DUCT UP AND CONNECT TO OUTDOOR AIR INTAKES AND 5'-0" FROM CHASSET WALLS. ALL GREASE DUCT IS TO BE INSTALLED WITH DUCT WHP AS DETAIL AND PER THE MANUFACTURER'S REQUIREMENTS FOR 0" CLEARANCE TO COMBUSTIBLES.
- (3) TRANSITION AND CONNECT 1/4" DIAMETER GREASE DUCT TO EXHAUST HOOD. ROUTE DUCT UP AND CONNECT TO