



### AIR BALANCE SCHEDULE

UNIT	AREA SERVED	HOOD ON OA		HOOD OFF OA		HOOD ON EXHAUST		HOOD OFF EXHAUST	
		DESIGN	ACTUAL	DESIGN	ACTUAL	DESIGN	ACTUAL	DESIGN	ACTUAL
RTU 1	SALES	800	803	350	361				
RTU-2	SALES	800	769	350	372				
RTU-3	BOH/KITCHEN	800	861	350	339				
EF-1	WOMEN'S RR					225	258	225	258
EF-2	MEN'S RR					525	473	525	473
EF-3	HOOD					1350	1248	0	0
<b>TOTALS</b>		<b>2400</b>	<b>2433</b>	<b>1050</b>	<b>1072</b>	<b>2100</b>	<b>1979</b>	<b>750</b>	<b>731</b>

#### HOODS ON

##### NET AIRFLOW CALCULATION

TOTALS	DESIGN	ACTUAL
TOTAL OA	2400	2433
TOTAL EXHAUST	2100	1979
<b>NET AIRFLOW</b>	<b>300</b>	<b>454</b>

DOOR TESTED	BUILDING PRESSURE MEASUREMENTS
FRONT	0.019
SIDE	
REAR	
<b>AVERAGE</b>	<b>0.019</b>

#### HOODS OFF

##### NET AIRFLOW CALCULATION

TOTALS	DESIGN	ACTUAL
TOTAL OA	1050	1072
TOTAL EXHAUST	750	731
<b>NET AIRFLOW</b>	<b>300</b>	<b>341</b>

DOOR TESTED	BUILDING PRESSURE MEASUREMENTS
FRONT	0.017
SIDE	
REAR	
<b>AVERAGE</b>	<b>0.017</b>

NOTES: