

CheckList List

- HOT WATER HEATER SCHEDULES
- HOT WATER SENSOR CALIBRATION



10-23-23 PERRY'S VERDAD - AUSTIN, TX (CX)

CheckList Information

Name : HOT WATER HEATER SCHEDULES **Status :** Completed
Assigned Organization : National TAB **Asset :**
Requesting Organization : National TAB
Created Date : 11/27/2023 - Dan Hertenstein - National TAB
Completed Date : 12/13/2023 - Wesley John - National TAB

CheckList Item Details

HOT WATER HEATER #1 OCC_SCHEDULE Pass

Comment:

HOT WATER HEATER #1 OCC_SETPOINT Pass

Comment:

145 DEG F.

HOT WATER HEATER #1 UNOCC_SETPOINT Pass

Comment:

HOT WATER HEATER #2 OCC_SCHEDULE Pass

Comment:

HOT WATER HEATER #2 OCC_SETPOINT Pass

Comment:

145 DEG F.

HOT WATER HEATER #2 UNOCC_SETPOINT Yes

Comment:



10-23-23 PERRY'S VERDAD - AUSTIN, TX (CX)

CheckList Information

Name : HOT WATER SENSOR CALIBRATION **Status :** Completed
Assigned Organization : National TAB **Asset :**
Requesting Organization : National TAB
Created Date : 11/27/2023 - Dan Hertenstein - National TAB
Completed Date : 12/13/2023 - Wesley John - National TAB

CheckList Item Details

Hot water heaters set to 140 deg F. Pass

Comment:

Water heater(s) increased to 145 deg due to loss of heat in lines to maintain required temperatures at each terminal sink

Aqua-stat set for 130 deg on, 140 deg off. Pass

Comment:

Single setpoint Aqua-Stat set to turn off at 135 deg to prevent short cycling of the pump

All Hand sinks have mixing valves to delivery 110 deg F. water Pass

Comment:

Yes

Mop Sinks and Triple Sink provide 140 deg water through hot water line Pass

Comment:

Yes

RECORD SINK TEMPERATURES

Hand wash beverage station sink Pass

Comment:

108 Deg F.

Mop sink

Pass

Comment:

143 Deg F.

Dishwashing - hand wash sink

Pass

Comment:

110 Deg F.

Triple Sink

Pass

Comment:

141 Deg F.

Back cook line - double sink

Pass

Comment:

140 Deg F.

Back cook line - hand sink

Pass

Comment:

108 Deg F.

Family restroom sink

Pass

Comment:

106 Deg F.

Women's restroom left sink

Pass

Comment:

105 Deg F.

Women's restroom right sink

Pass

Comment:

107 Deg F.

Men's restroom left sink

Pass

Comment:

106 Deg F.

Men's restroom right sink

Pass

Comment:

110 Deg F.

Bar sink 1

Pass

Comment:

107 Deg F.

Bar sink 2

Pass

Comment:

105 Deg F.

Bar sink 3

Pass

Comment:

106 Deg F.