

- 1. TO SERVE ASSOCIATED HOODS. USE CAPTURE RATE PLANS TO DETERMINE CAPTURE RATE AND MAKE CONFORMANCE WITH NFPA 96 LOCAL CODES, AND SIZE HOODS AND EXHAUST SYSTEMS ACCORDINGLY.
- 2. SYSTEM SHALL BE MOUNTED TO END OF HOOD.
- 3. INSTALL MANUAL PULL STATION FOR HOOD FIRE SUPPRESSION SYSTEM. VERIFY LOCATION AND QUANTITY PRIOR TO INSTALLATION.
- 4. PROVIDE FIELD FABRICATED PLENUM BOX EXTENDED AS NECESSARY TO MAINTAIN CLEARANCE FROM HOODS AND ARCHITECTURAL ROP.
- 5. DUCT SMOKE DETECTOR PROVIDED BY DIVISION 28.
- 6. PROVIDE FIELD FABRICATED PLENUM BOX EXTENDED AS NECESSARY TO MAINTAIN CLEARANCE FROM HOODS AND ARCHITECTURAL ROP.
- 7. MOUNT FOU-1000A/F.F.
- 8. MOUNT FOU-1000A/F.F.
- 9. MOUNT FOU-1000A/F.F.
- 10. NECESSARY FOR TYPE 1 GREASE HOOD EXHAUST.

REMARKS: CLEANOUT SHALL BE AS FAR AS PRACTICABLE FROM THE HOOD. PROVIDE PROPER CLEARANCE IN FRONT OF CLEANOUT FOR ACCESS.

MANUFACTURERS INSTALLATION GUIDELINES.

