


- PLAN NOTES**
1. OUTDOOR THROUGH EXISTING WALL AS REQUIRED TO ROUTE NEW MECHANICAL PIPING. SEAL PENETRATION WITH GROUT. TYPICAL.
 2. OUTDOOR THROUGH EXISTING FLOOR AS REQUIRED TO ROUTE NEW MECHANICAL PIPING. PROVIDE AND INSTALL FLOOR SLEEVE AND SEAL WITH GROUT.
 3. EXPOSED PIPING SHALL BE PVC JACKETED.
 4. ROUTE CONDENSATE PIPING EXPOSED ON WALL/FLOOR TO NEAREST FLOOR DRAIN.
 5. REFER TO SHEET M302B FOR CONTINUATION.
 6. REFER TO SHEET M301A FOR CONTINUATION.
 7. REFER TO SHEET M301C FOR CONTINUATION.



FIRST FLOOR MECHANICAL PIPING PLAN - UNIT B
SCALE: 1/8" = 1'-0"

ISSUED FOR CONSTRUCTION 07-06-2021

File Location = K:\2016\Lawrenceburg HS Renovation\105 Revolving\Mech\Sheet Name = 105M01B.dwg Date Plotted = 7/6/21 Time Plotted = 8:35:42 AM Plotted By = John Copyright Primary Engineering, Inc.

0 16 32 48 0 8 16 24 32 0 8 16 24 0 4 8 12 0 2 4 6 0 2 4 0 1 2 3
SCALE: 1/16" = 1'-0" SCALE: 3/32" = 1'-0" SCALE: 1/8" = 1'-0" SCALE: 1/4" = 1'-0" SCALE: 1/2" = 1'-0" SCALE: 3/4" = 1'-0" SCALE: 1" = 1'-0"

LANCER + BEEBE


PRIMARY ENGINEERING, INC.
Indianapolis
2150 Cassin Road, Suite 103
Indianapolis, Indiana 46226
317.294.1221 ph
info@primary-eng.com
www.primary-eng.com

LAWRENCEBURG HIGH SCHOOL
INTERIOR RENOVATIONS
100 TIGER BOULEVARD
LAWRENCEBURG, IN 47025


PROJECT: #20102
DATE: 04/07/2021
Date Desc
1 04/30/21 ADD EG

1ST FLR MECH PIPING PLAN UNIT B
M301B

PRIMARY JOB #20102



- PLAN NOTES**
1. CUTCORE THROUGH EXISTING WALL AS REQUIRED TO ROUTE NEW MECHANICAL PIPING. SEAL PENETRATION WITH GROUT. TYPICAL.
 2. CUTCORE THROUGH EXISTING FLOOR AS REQUIRED TO ROUTE NEW MECHANICAL PIPING. PROVIDE AND INSTALL FLOOR SLEEVE AND SEAL WITH GROUT.
 3. RECONNECT NEW CABINET UNIT HEATER TO EXISTING PIPING.
 4. REFER TO SHEET M301B FOR CONTINUATION.
 5. REFER TO SHEET M301D FOR CONTINUATION.
 6. REFER TO SHEET M403 FOR CONTINUATION.



FIRST FLOOR MECHANICAL PIPING PLAN - UNIT C

ISSUED FOR CONSTRUCTION 07-06-2021



File Location = K:\2016\2016 Lawrenceburg HS Renovation\165 Renovation\165_Sheet\165_01 First Floor Unit C - 07-06-21.dwg Plot Date = 07-06-21 10:58:58 AM Plotted By = jpmay Copyright Primary Engineering, Inc.

LANCER + BEEBE

PRIMARY ENGINEERING, INC.
Fort Wayne, IN

220 N. College Ave
Indianapolis, IN 46202

317.294.1221
info@primary-eng.com

LAWRENCEBURG HIGH SCHOOL
INTERIOR RENOVATIONS
100 TIGER BOULEVARD
LAWRENCEBURG, IN 47025

REGISTERED PROFESSIONAL ENGINEER
STATE OF INDIANA
PE11700017

PROJECT: #20102
DATE: 04/07/2021



#	Date	Desc.

1ST FLR MECH PIPING PLAN UNIT C
M301C

KEYPLAN
MS

PRIMARY JOB #20102

PLAN NOTES	
1.	REFER TO SHEET M301C FOR CONTINUATION.
2.	REFER TO SHEET M403 FOR CONTINUATION.



FIRST FLOOR MECHANICAL PIPING PLAN - UNIT D
SCALE: 1/8" = 1'-0"


ISSUED FOR CONSTRUCTION 07-06-2021



LANCER + BEEBE
 220 N. College Ave
 Indianapolis, IN 46202

PRIMARY ENGINEERING, INC.
 Fort Wayne
 1500 S. State St., Suite 103
 Indianapolis, Indiana 46226
 317.334.1221 ph
 info@primary-eng.com
 www.primary-eng.com


LAWRENCEBURG HIGH SCHOOL
 INTERIOR RENOVATIONS
 100 TIGER BOULEVARD
 LAWRENCEBURG, IN 47025



PROJECT: #20102	Disc.
DATE: 04/07/2021	
#	Date

1ST FLR
 MECH
 PIPING
 PLAN
 UNIT D
 M301D


File Location = K:\2010\20 Lawrenceburg HS Renovations\1st Floor\Mech\1st Flr Mech - 07-06-21\1st Flr Mech - 07-06-21.dwg
 Plot Date = 07-06-21 10:00:00 AM
 Plot Scale = 1/8" = 1'-0"
 Plot Size = 11.00 x 17.00
 Plot Orientation = Landscape
 Plot Title = 1ST FLR MECH PIPING PLAN - UNIT D
 Plot User = jsmith



- PLAN NOTES**
1. OUTCORE THROUGH EXISTING WALL AS REQUIRED TO ROUTE NEW MECHANICAL PIPING. SEAL PENETRATION WITH GROUT. TYPICAL.
 2. ROUTE CONDENSATE PIPING EXPOSED ON WALL/FLOOR TO NEAREST FLOOR DRAIN.
 3. REFER TO DRAWING SHEET M302B FOR CONTINUATION.
 4. CORE THROUGH EXISTING WALL AS REQUIRED TO ROUTE CONDENSATE PIPING ON ROOF, APPROXIMATELY 18" ABOVE ROOF. SEAL PENETRATION WITH GROUT.

SECOND FLOOR MECHANICAL PIPING PLAN - UNIT A
SCALE: 1/8" = 1'-0"

ISSUED FOR CONSTRUCTION 07-06-2021



LANCER + BEEBE

PRIMARY ENGINEERING, INC.
Fort Wayne
Indianapolis
Bldg. Suite 103
Indianapolis, Indiana 46226
317.324.1221 ph
info@primary-eng.com
www.primary-eng.com

**LAWRENCEBURG HIGH SCHOOL
INTERIOR RENOVATIONS
100 TIGER BOULEVARD
LAWRENCEBURG, IN 47025**




PROJECT: #20102	DATE: 04/07/2021
#	Date

2ND FLR
MECH
PIPING
PLAN
UNIT A
M302A

PRIMARY JOB #20102

File Location = K:\2010\20 Lawrenceburg HS Renovations\2D Revolving\Mech\Sheet\Name = 100M302A.dwg Date Plotted = 7:49:51 Time Plotted = 46.05 by AAI Plotted by - Primary Engineering Inc.


File Location = K:\2016\Lawrenceburg High School Renovations\2D\Mechanical\2D\Mechanical - 07-06-21\2D\Mechanical - 07-06-21.dwg Plot Date = 07/06/2021 10:48:21 AM Printed By = Primary Engineering Inc.



- PLAN NOTES**
1. OUTCORE THROUGH EXISTING WALL AS REQUIRED TO ROUTE NEW MECHANICAL PIPING. SEAL PENETRATION WITH GROUT. TYPICAL.
 2. OUTCORE THROUGH EXISTING FLOOR AS REQUIRED TO ROUTE NEW MECHANICAL PIPING. PROVIDE AND INSTALL FLOOR SLEEVE AND SEAL WITH GROUT.
 3. REFER TO SHEET M302A FOR CONTINUATION.
 4. REFER TO SHEET M301B FOR CONTINUATION.
 5. REFER TO SHEET M402 FOR CONTINUATION.
 6. REFER TO SHEET M303B FOR CONTINUATION.

SECOND FLOOR MECHANICAL PIPING PLAN - UNIT B
SCALE: 1/8" = 1'-0"

ISSUED FOR CONSTRUCTION 07-06-2021



LANCER + BEEBE


PRIMARY ENGINEERING, INC.
Indianapolis
13500 Shadeland Blvd., Suite 103
Indianapolis, IN 46226
317.334.1221
info@primary-eng.com
www.primary-eng.com

LAWRENCEBURG HIGH SCHOOL
INTERIOR RENOVATIONS
100 TIGER BOULEVARD
LAWRENCEBURG, IN 47025




PROJECT: #20102	DATE: 04/07/2021	DATE: 04/07/2021	DATE: 04/07/2021
DESIGNER: J. W. BEEBE	CHECKER: J. W. BEEBE	DATE: 04/07/2021	DATE: 04/07/2021
PROJECT: #20102	DATE: 04/07/2021	DATE: 04/07/2021	DATE: 04/07/2021

2ND FLR MECH PIPING PLAN UNIT B M302B
PRIMARY JOB #20102



THIRD FLOOR MECHANICAL PIPING PLAN - UNIT A
SCALE: 1/8" = 1'-0"

- PLAN NOTES**
1. OUTCORE THROUGH EXISTING WALL AS REQUIRED TO ROUTE NEW MECHANICAL PIPING. SEAL PENETRATION WITH GROUT. TYPICAL.
 2. REFER TO SHEET M303B FOR CONTINUATION.



File Location = K:\2016\Lawrenceburg HS Renovations\103 Revolving\103 Revolving\103 Revolving - 08-24-16.dwg Date Printed = 1/26/22 Time Printed = 10:24:05 AM Plot by = substack Copyright Primary Engineering, Inc.

LANCER + BEEBE

PRIMARY ENGINEERING, INC.
Indianapolis
185 Cobblestone Blvd, Suite 103
317.334.1221 ph
info@primary-eng.com
www.primary-eng.com

LAWRENCEBURG HIGH SCHOOL
INTERIOR RENOVATIONS
100 TIGER BOULEVARD
LAWRENCEBURG, IN 47025


PROJECT: #20102
DATE: 04/07/2021
1 Date 02/27/22
T. 02/27/22 PR. ES.

3RD FLR MECH PIPING PLAN UNIT A
M303A

PRIMARY JOB #20160


File Location = K:\2016\Lawrenceburg HS Renovation\15 Rev\Working\04072021\Sheet\Name - 150405.dwg Date Plotted = 7/6/21 Time Plotted = 10:26:10 AM Plotted by - Primary Copyright Primary Engineering, Inc.

PLAN NOTES	
1.	OUTCORE THROUGH EXISTING WALL AS REQUIRED TO ROUTE NEW MECHANICAL PIPING. SEAL PENETRATION WITH GROUT. TYPICAL.
2.	REFER TO SHEET M304B FOR CONTINUATION.



FOURTH FLOOR MECHANICAL PIPING PLAN - UNIT A
SCALE: 1/8" = 1'-0"

ISSUED FOR CONSTRUCTION 07-06-2021



KEYPLAN
MS



LANCER + BEEBE
PRIMARY ENGINEERING, INC. Fort Wayne
 Indianapolis
 1500 College Ave., Suite 103
 Fort Wayne, Indiana 46826
 317.334.1221 ph
 info@primary-eng.com
 www.primary-eng.com

LAWRENCEBURG HIGH SCHOOL
 INTERIOR RENOVATIONS
 100 TIGER BOULEVARD
 LAWRENCEBURG, IN 47025


PROJECT: #20102
 DATE: 04/07/2021
 # | Date | Desc.

4TH FLR
 MECH
 PIPING
 PLAN
 UNIT A
 M304A


PRIMARY JOB #20102

File Location = K:\2016\Lawrenceburg HS Renovation\105 Revolving\105 Revolving\105 Revolving.dwg Date Plotted = 7/6/21 Time Plotted = 10:26:10 AM Plotted by = jblinn Copyright Primary Engineering, Inc.

PLAN NOTES	
1.	REFER TO SHEET M303B FOR CONTINUATION.
2.	REFER TO SHEET M304A FOR CONTINUATION.



FOURTH FLOOR MECHANICAL PIPING PLAN - UNIT B
SCALE: 1/8" = 1'-0"



KEYPLAN
MS

0 16 32 48 0 8 16 24 32 0 8 16 24 0 4 8 12 0 2 4 6 0 1 2 4 0 1 2 3
SCALE: 1/16" = 1'-0" SCALE: 3/32" = 1'-0" SCALE: 1/8" = 1'-0" SCALE: 1/4" = 1'-0" SCALE: 1/2" = 1'-0" SCALE: 3/4" = 1'-0" SCALE: 1" = 1'-0"

ISSUED FOR CONSTRUCTION 07-06-2021

LANCER + BEEBE
PRIMARY ENGINEERING, INC. Fort Wayne
 Indianapolis
 1500 College Ave., Suite 103
 Fort Wayne, Indiana 46826
 317.334.1221 ph
 info@primary-eng.com
 www.primary-eng.com

LAWRENCEBURG HIGH SCHOOL
INTERIOR RENOVATIONS
100 TIGER BOULEVARD
LAWRENCEBURG, IN 47025



PROJECT: #20102	DATE: 04/07/2021	Disc.
# 1	04/30/21	ADD. EG.


4TH FLR
 MECH
 PIPING
 PLAN
 UNIT B
 M304B

PRIMARY JOB #20102


PRIOR TO STARTUP OF NEW HYDRONIC EQUIPMENT, THE CONTRACTOR SHALL FULLY DRAIN ALL SYSTEM FLUID INCLUDING NEW AND EXISTING MAIN PIPING, BRANCH PIPING, AND COILS. THE CONTRACTOR SHALL REPEATEDLY FLUSH AND DRAIN THE PIPING SYSTEM IN ITS ENTIRETY WITH COLD WATER AND CHEMICAL DETERGENT UNTIL SYSTEM FLUID IS CLEAR.

DURING SUMMER 2021 PHASE AND PRIOR TO ANY PIPING OR EQUIPMENT DEMOLITION, THE CONTRACTOR SHALL FULLY DRAIN ALL SYSTEM FLUID INCLUDING NEW AND EXISTING MAIN PIPING, BRANCH PIPING, AND COILS. THE CONTRACTOR SHALL REPEATEDLY FLUSH AND DRAIN THE PIPING SYSTEM IN ITS ENTIRETY WITH COLD WATER AND CHEMICAL DETERGENT UNTIL SYSTEM FLUID IS CLEAR.


- PLAN NOTES**
- FOUR NEW 4" CONCRETE HOUSEKEEPING PAD EXTENDING 8" BEYOND ALL NEW EQUIPMENT. CONTRACTOR SHALL EMPLOY PROPER TRADES TO PATCH OPENINGS IN BUILDING CONSTRUCTION AND FINISH SURFACES TO MATCH ADJACENT AREAS. COORDINATE WITH G.C.
 - EXISTING CHILLED WATER HYDRONIC MAINS TO GREENDALE MIDDLE SCHOOL. CAP AND SEAL AIRWATER TIGHT AT TOP OF CHASE.
 - MAINTAIN ALL MANUFACTURER'S REQUIRED SERVICE CLEARANCES FOR SERVICE ACCESS, TYPICAL.
 - ROUTE ALL BOILERWATER HEATER CONDENSATE PIPING TO FACTORY PROVIDED CONDENSATE NEUTRALIZATION KITS. ALL CONDENSATE PIPING SHALL BE SOLVENT WELDED SCHEDULE 80 PVC. ROUTE PIPING TO NEAREST FLOOR DRAIN/FLOOR SINK.
 - ROUTE REFRIGERANT EXHAUST DUCTWORK DOWN TO EXHAUST GRILLE INSTALLED AT APPROXIMATELY 12" AFF.
 - REFER TO SYSTEM FILL STATION DETAIL ON DRAWING SHEET M602 FOR ADDITIONAL INFORMATION.
 - PROVIDE AND INSTALL CHEMICAL TREATMENT SYSTEM. REFER TO CHEMICAL SHOT FEEDER DETAIL ON DRAWING SHEET M602 AND SPECIFICATIONS FOR ADDITIONAL INFORMATION.
 - ROUTE 3/4" BLOW DOWN DRAIN PIPING FROM AIR/DIRT SEPARATOR TO SYSTEM FILL STATION WITH VALVE LOCATED APPROXIMATELY 48" AFF.
 - REFER TO VARIABLE SPEED PUMP ASSEMBLY DETAIL ON DRAWING SHEET M402 FOR ADDITIONAL INFORMATION, TYPICAL.
 - PROVIDE AND INSTALL ISOLATION VALVE ON ALL PIPING EXITING BOILER ROOM PRIOR TO WALL PENETRATIONS, TYPICAL.
 - REFRIGERANT LEAK DETECTION AUDIO/VISUAL ALARM WITH ENGRAVED LABEL, BY TCC.
 - ROOF MOUNTED REFRIGERANT EXHAUST FAN, INTERLOCKED WITH REFRIGERANT LEAK DETECTION PANEL.
 - BOILER FLUES SHALL BE DOUBLE WALL STAINLESS STEEL. PROVIDE AND INSTALL PER MANUFACTURER'S VENTING REQUIREMENTS.
 - ROUTE INTAKE AND FLUE PIPING UP THROUGH ROOF AND SEAL AIRWATER TIGHT.
 - VARIABLE SPEED DRIVES FURNISHED BY TCC. PROVIDE AND INSTALL RACKS FOR MOUNTING IN LOCATION SHOWN, TYPICAL OF 5.
 - INSTALL UNIT HEATER AT APPROXIMATELY 7' AFF. SUSPEND FROM STRUCTURE AS REQUIRED.
 - RELOCATE EXISTING TCC AIR COMPRESSOR TO NEW LOCATION SHOWN DURING PHASE 1. MAINTAIN SERVICE THROUGHOUT CONSTRUCTION.
 - REFER TO BOILER ROOM BALCONY MECHANICAL PLAN FOR CONTINUATION.
 - REFER TO BOILER ROOM MECHANICAL PLAN FOR CONTINUATION.
 - REFER TO DRAWING SHEET M301B FOR CONTINUATION.



5 BOILER ROOM BOILER AND WATER HEATER FLUE AND INTAKE PLAN
SCALE: 1/8"=1'-0"



4 BOILER ROOM BALCONY MECHANICAL PLAN
SCALE: 1/4"=1'-0"



3 BOILER ROOM MECHANICAL PLAN
SCALE: 1/4"=1'-0"



File Location = K:\2016\Lawrenceburg High School\Interior Renovations\Boiler Room - 21-16-22.dwg Date Plotted = 10/14/21 10:17:41 AM Plotted by = kasper Copyright Primary Engineering, Inc.

LANCER + BEEBE

PRIMARY ENGINEERING, INC.
Fort Wayne
Indianapolis

Box 103
1850 Coliseum Blvd
Lawrenceburg, IN 47025
317.324.1221 ph
info@primary-eng.com
www.primary-eng.com

LAWRENCEBURG HIGH SCHOOL
INTERIOR RENOVATIONS
100 TIGER BOULEVARD
LAWRENCEBURG, IN 47025


PROJECT: #20102
DATE: 04/07/2021
Date
2 01/19/22
Dir: ESK/AT
Dir: ESK/AT

REGISTERED PROFESSIONAL ENGINEER
STATE OF INDIANA
PE11700017

M401


PRIMARY JOB #20102

File Location = K:\2021\Lawrenceburg High School\Interior Renovations\2nd Floor\Mechanical\2nd Floor Mechanical Plan.dwg Date Plotted = 7/2/21 Time Plotted = 10:58:30 AM Plotted by = John Copyright Primary Engineering, Inc.




3 SECOND FLOOR MECHANICAL ROOM MECHANICAL PLAN

SCALE: 1/4" = 1'-0" SCALE: 3/32" = 1'-0" SCALE: 1/8" = 1'-0"



2 SECOND FLOOR MECHANICAL ROOM MECHANICAL PLAN


SCALE: 1/4" = 1'-0" SCALE: 1/2" = 1'-0"



1 SECOND FLOOR MECHANICAL ROOM MECHANICAL PLAN

SCALE: 3/4" = 1'-0" SCALE: 1" = 1'-0"

- PLAN NOTES**
- CUTCORE THROUGH EXISTING WALL AS REQUIRED TO ROUTE NEW DUCTWORK/PIPING. PATCH SURFACES TO MATCH ADJACENT.
 - CUTCORE EXISTING ROOF AS REQUIRED TO ROUTE NEW DUCTWORK/PIPING. PATCH ROOF AS REQUIRED. MAINTAIN ROOF WARRANTY.
 - PROVIDE AND INSTALL NEW LOUVER IN EXISTING OPENING.
 - ROUTE CONDENSATE PIPING EXPOSED ON FLOOR TO NEAREST FLOOR DRAIN.
 - PROVIDE AND INSTALL NEW ROOF CURB FOR DUCTWORK UP TO RTU-1.
 - ROUTE HOT WATER PIPING UP WITHIN RTU-1 CABINET.
 - CAP AND ABANDON LOUVER WITH 4" THICK RIGID INSULATION AND SHEET METAL SEALED WITH SILICONE SEALANT.
 - REFER TO STRUCTURAL DRAWINGS FOR ROOF OPENING DETAILS.
 - ALL NATATORIUM DUCTWORK SHALL BE ALUMINUM. REFER TO SPECIFICATIONS.



KEYPLAN

ISSUED FOR CONSTRUCTION 07-06-2021

LANCER + BEEBE

PRIMARY ENGINEERING, INC. Fort Wayne, IN

LAWRENCEBURG HIGH SCHOOL INTERIOR RENOVATIONS
100 TIGER BOULEVARD
LAWRENCEBURG, IN 47025

PROJECT: #20102
DATE: 04/07/2021
BY: DMB
CHECKED: JMB
DATE: 04/22/21
ADD: JH

REGISTERED PROFESSIONAL ENGINEER
STATE OF INDIANA
PE11700017

ENLARGED 2ND FLR MECH PLAN

M403

PRIMARY JOB #20102