

Issue List

- RTU's OA DAMPERS



09-22-25 POTTERY BARN KIDS #0495 DURHAM, NC


Project Issue Information

Issue Name : RTU's OA DAMPERS
Description : OA/Fresh Air setting not installed & not able to be configured. Troubleshooted main board and fresh air board. Found that ICM CABLE was not connected to board, wires are too short
Created By : National TAB **Assigned To :** National TAB - Dan Hertenstein
Status : Open
Priority : Urgent **Asset Tag :**
Originated Date : 09/25/2025 - Cody Mauro - National TAB

Project Issue File Details



09/25/2025



09/25/2025



09/25/2025