



DUCTWORK #1 PARTS - JOB#4821270 DOUBLE WALL DUCT

TAG	PART #	CFM	GPM	ZONE	COVEREDBY	SP	WEIGHT	VELOCITY	QTY	DESCRIPTION
P1	DW1227DWAJD-2R-S	1495				-0.011	45.95	1903.49	1	DOUBLE WALL ADJUSTABLE DUCT - 12" INNER DUCT - 2 LAYERS REDUCED CLEARANCE - 16" STAINLESS STEEL OUTER SHELL. MIN LENGTH = 11' / MAX LENGTH = 24.5' / ADJUSTMENT = 19.5' / ADJUSTABLE SECTION MAY NEED TO BE CUT. INCLUDES SINGLE AND DOUBLE WALL "V" CLAMPS.
P2	DW1290DWASY-2R-S	1495				-0.1485	27.16	1903.49	1	DOUBLE WALL DUCT - 12" INNER 90 DUCT - 2 LAYERS REDUCED CLEARANCE - 16" STAINLESS STEEL OUTER SHELL.
P3 ASSEMBLED W/P4	DW1227DWAJDTP-2R-S	1495				-0.011	45.74	1903.49	1	DOUBLE WALL ADJUSTABLE DUCT TRANSITION PLATE - 12" INNER DUCT - 2 LAYERS REDUCED CLEARANCE - 16" STAINLESS STEEL OUTER SHELL. MIN LENGTH = 11' / MAX LENGTH = 24.5' / ADJUSTMENT = 6.5' / ADJUSTABLE SECTION MAY NEED TO BE CUT. INCLUDES SINGLE AND DOUBLE WALL "V" CLAMPS.
P4 ASSEMBLED W/P3 SYSTEM AT P4	DW2312TPBEX	1495					8.00	1903.49	1	DUCT TO CURB TRANSITION 3/4" DOWN TURN, 23" CURB TO 12" DUCT, 16 GA ALUMINIZED. USED ON NICALAPA & NICALAPPA. TRANSITION PLATE DD IS 23.5" DESIGNED FOR USE WITH EXHAUST FAN. NON-STANDARD PART.
	3M-2000PLUS					-0.6275	0.80		1	DUCT - 3M FIRE BARRIER 2000 PLUS SILICONE - USED AS SEALANT TO SEAL DUCT JOINTS.
TOTAL WEIGHT							127.65			


DUCTWORK #1 TOP VIEW
DUCT




DUCTWORK #1 FRONT VIEW
DUCT



DUCTWORK #1 SE VIEW
DUCT



DUCTWORK #1 SIDE VIEW
DUCT



REVISIONS

NO.	DATE	DESCRIPTION
1		



Man Cave Rv1
2815 Factory Rd,
Springboro, OH, 45066

DATE: 9/29/2021

DWG.#:
4821270

DRAWN
BY:

SCALE:
Not To Scale

MASTER DRAWING

SHEET NO.
1