



- DRAWING NOTES**
- NO WORK
 - KITCHEN HOOD AND MAKEUP AIR TO BE PROVIDED AND PERMITTED BY OTHERS.
 - DUCT TO BE INSULATED WITH EXTERIOR INSULATION WRAP.
 - OUTSIDE AIR LOUVER PROVIDED BY OTHERS.
 - INLINE FAN TO PROVIDE OA TO ALL SPLIT SYSTEM AIR HANDLERS.
 - SMOKE DETECTOR TO SHUT DOWN AIR HANDLER UPON THE PRESENCE OF SMOKE. BUILDING FIRE ALARM COMPONENTS (AUDIO AND VISUAL) AND ALARM INTEGRATION WIRING TO BE PROVIDED BY FIRE ALARM CONTRACTOR.
 - CONDENSATE (NOT SHOWN FOR CLARITY) TO BE ROUTED TO MOP SINK OR FREEZER AREA FLOOR DRAIN AS COORDINATED IN THE FIELD.
 - REFRIGERANT LINES TO BE ROUTED UP EXISTING SHAFT AND OUT OF A NEW 30" CURB (BY OTHERS) TO HEAT PUMPS ON THE ROOF.
 - DOOR TO BE UNDERCUT 1" BY G.C. TO ALLOW FOR MAKEUP OF EXHAUSTED AIR.
 - THIS PORTION OF EXPOSED DUCTWORK TO BE ORDERED AS "PAINT GRIP."
 - CONDENSING UNITS MOUNTED ON ROOF. FINAL LOCATIONS AROUND SHAFT TO BE FIELD VERIFIED.
 - AUXILIARY DRAIN PAN AND WET SWITCH COMPLIANT WITH OMC 307.2.3 TO BE INSTALLED AT UNIT (NOT SHOWN FOR CLARITY).
 - 1" LINED OUTDOOR AIR DUCT (ONLY WHERE INDICATED BY CODED NOTE CALL OUT).
 - EXISTING CEILING EXHAUST FAN AND DISCHARGE DUCT STUBBED OUT BEYOND DRYWALL CEILING.
 - SPACE TEMPERATURE SENSOR. ASSOCIATED THERMOSTAT IS LOCATED IN OFFICE (NO PUBLIC ACCESS).
 - FREEZER BY OTHERS.

SECOND FLOOR HVAC PLAN
SCALE: 1/4" = 1'-0"

REVISIONS	DATE:	DESCRIPTION:
	8/8/25	ISSUED FOR PERMIT

PROFESSIONAL STAMP

The Cincinnati Air Conditioning Company
cac
EST. 1938

Commercial Air Conditioning
Process Piping
Refrigeration
Heating

PH: 513-721-5622
FAX: 513-345-2544
2080 Northwest Dr.
Cin. OH, 45231

CONCORDE RESTAURANT
4919 WEISSL AVENUE
CINCINNATI, OH 45227
HVAC DRAWING

DRAWING SCALE:	1/4" = 1'-0"
DATE DRAWN:	08/04/25
DRAWN BY:	SCOTT HOEPLER
JOB #	C-65533
DRAWING #	6406
SHEET #	M-100