



VERIFY ALL EXISTING EXHAUST OUTLETS WITHIN 10'-0" OF OUTDOOR AIR INTAKES ARE MINIMUM 3'-0" HIGHER THAN OUTDOOR AIR INTAKES. CONTACT THE ARCHITECT AND ENGINEER IMMEDIATELY IF ANY EXISTING EXHAUST OUTLETS WITHIN 10'-0" OF OUTDOOR AIR INTAKES ARE OBSERVED TO BE LESS THAN 3'-0" HIGHER THAN OUTDOOR AIR INTAKES.

- 13. IF NOT PRINTED, ALL DUCTWORK EXPOSED DUCTWORK IN THE DINING AREA SHALL BE GALVANIZED STEEL (P/S) SPECIFICATIONS FOR ADDITIONAL SHEETS.
- 14. COORDINATE ACCESS PANEL LOCATION.
- 15. SHEETS.