


CAPTIVE AIR PREFORATED DUCT
18ø



ELEVATE DUCT TO KEEP SPIRAL
HIGH AS POSSIBLE TO BEAM.
LEAVE APPROX 4" ABOVE DUCT
FOR FP & CONDUITS OVER TOP
OF DUCT.

ELEVATE DUCT TO KEEP SPIRAL
HIGH AS POSSIBLE TO BEAM.
LEAVE APPROX 4" ABOVE DUCT
FOR FP & CONDUITS OVER TOP
OF DUCT.

CAPTIVE AIR PREFORATED DUCT
16ø

CAPTIVE AIR PREFORATED DUCT
16ø

CAPTIVE AIR
DUCT THRU
WALL

DUCT CONN.
FROM CAPTIVE
AIR DUCT TO
PROVIDED
DUCT THRU
BY M.C.

WRAPPED ROUND S/A
DUCT ABOVE CEILING (TYP)

TRANSITION TO 2X12
DUCT AND ROUTE EF-6
ON ROOF.

15" UNDERCUT

WATER HEATER