



Nestle (Mt Sterling, KY)

CheckList Information

Name :	EF-23-06 / L4 OVEN EXHAUST STACK	Status :	NotSubmitted
Assigned Organization :	National TAB	Asset :	
Requesting Organization :	National TAB		

CheckList Item Details

Observe Unit to ensure operational and no visual issues. If any observed, comment. Note # of duct drops.	No visible issues
Make, Model, and Serial Number:	Unit data: NYB B05825-100 174LS Motor 3hp 460 4.5a
Attach picture of asset.	Yes
<ul style="list-style-type: none"> • Open File.jpg 	
Fan CFM:	Vel: 2725 10" Cfm: 1499
Fan total pressure recorded.	Yes
<ul style="list-style-type: none"> • Open File.jpg 	
Is Fan interlocked with any other asset? if so, list:	L4 oven
When is fan used (application) and any specific time?	L4 oven