



Nestle (Mt Sterling, KY)

CheckList Information

Name :	EF-28-06 / L4 OVEN INFEED HOOD	Status :	NotSubmitted
Assigned Organization :	National TAB	Asset :	
Requesting Organization :	National TAB		

CheckList Item Details

Observe Unit to ensure operational and no visual issues. If any observed, comment. Note # of duct drops.	Bottom plate of fan is off
<ul style="list-style-type: none"> • Open File.jpg 	
Make, Model, and Serial Number:	
Attach picture of asset.	Yes
<ul style="list-style-type: none"> • Open File.jpg 	
Fan CFM:	2046
Fan total pressure recorded.	Yes
<ul style="list-style-type: none"> • Open File.jpg 	
Is Fan interlocked with any other asset? if so, list:	L4 infeed hood Unit data: Sn: 2017-09927-01 17LS Motor: 3 460 4.5A Vel: 3720 10" Cfm:2046
When is fan used (application) and any specific time?	L4 freezer infeed hood