



Nestle (Mt Sterling, KY)

CheckList Information

Name :	EF-5-93 MAINTENANCE SHOP EAST	Status :	NotSubmitted
Assigned Organization :	National TAB	Asset :	
Requesting Organization :	National TAB		

CheckList Item Details

Observe Unit to ensure operational and no visual issues. If any observed, comment. Note # of duct drops.	No visual issues Pulley does look adjustable but access is difficult
Attach picture of asset.	Yes
<ul style="list-style-type: none"> • Open File.jpg 	
Fan total pressure recorded.	Yes
Is Fan interlocked with any other asset? if so, list:	No operated by its own switch
When is fan used (application) and any specific time?	Hear evac in summer
Make, Model, and Serial Number:	Unit data: Hartzell 63-36-LJ3 Serial : 9302560-02 2hp 1800 rpm 460 6.2
Fan CFM:	937 fpm 0.148 discharge