



Nestle (Mt Sterling, KY)

CheckList Information

Name :	EF-22-96 OVEN ROOM EXHAUST	Status :	Submitted
Assigned Organization :	National TAB	Asset :	
Requesting Organization :	National TAB		

CheckList Item Details

Observe Unit to ensure operational and no visual issues. If any observed, comment. Note # of duct drops.	Unit not running disconnect is on
Make, Model, and Serial Number:	Make:Stanley fans Model:HREBc30 Serial:B21247 Motor is .5hp 460v no amps listed
Attach picture of asset.	Yes
<ul style="list-style-type: none"> • Open File.jpg 	
Fan CFM:	0
Fan total pressure recorded.	No
Is Fan interlocked with any other asset? if so, list:	NA
When is fan used (application) and any specific time?	NA