



## Nestle (Mt Sterling, KY)

### CheckList Information

<b>Name :</b>	SF-2-98 SAUCE ROOM @ LINE 5	<b>Status :</b>	NotSubmitted
<b>Assigned Organization :</b>	National TAB	<b>Asset :</b>	
<b>Requesting Organization :</b>	National TAB		

### CheckList Item Details

**MAU**

UNIT DATA:	Unit does not run Make: Hartzell Model: 161-42-LK7 Serial: 9802288-05 3 HP 460V 4.3A 1750RPM
Unit Has Exhaust\Relief Fans & How Many. Note N/A if this does not apply.	NA
Verify outside air damper position & note approximate open amount (visual). Attached Picture	100%
No Relief/Exhaust in Operation @ Time of Testing. Note "N/A" if this system does not have Relief/Exhaust	NA
Fan Total Pressure Recorded	NA
Fan VFD Speed (HZ)	0
OA Damper Position (Controls Output) include picture of damper position.	100%
Attach picture of each asset	Yes
<ul style="list-style-type: none"> <li>• <a href="#">Open</a> File.jpg</li> </ul>	
CFM:	0 CFM UNIT DOES NOT RUN