



Nestle (Mt Sterling, KY)

CheckList Information

Name :	FF-1-93 PACK MEZZ	Status :	NotSubmitted
Assigned Organization :	National TAB	Asset :	
Requesting Organization :	National TAB		

CheckList Item Details

MAU

Observe unit to ensure operational & no visual issue. If any comment. Note # of Supply & Return Drops.	Make: Hartzell Model 15 24 P13 Serial: 9505507 1.5 HP 1800RPM 460V 2.7A
Unit Has Exhaust\Relieft Fans & How Many. Note N/A if this does not apply.	NA
Verify outside air damper position & note approximate open amount (visual). Attached Picture	Damper opens
No Relief/Exhaust in Operation @ Time of Testing. Note "N/A" if this system does not have Relief/Exhaust	NA
Fan Total Pressure Recorded	0.32"
Fan VFD Speed (HZ)	60HZ
OA Damper Position (Controls Output)	100%
Attach picture of each asset	Yes
<ul style="list-style-type: none"> • Open File.jpg 	
Make, Model, and Serial Number:	Make: Hartzell Model 15 24 P13 Serial: 9505507 1.5 HP 1800RPM 460V 2.7A
Fan CFM:	