



Nestle (Mt Sterling, KY)

CheckList Information

Name :	EF-48	Status :	NotSubmitted
Assigned Organization :	National TAB	Asset :	
Requesting Organization :	National TAB		

CheckList Item Details

Observe Unit to ensure operational and no visual issues. If any observed, comment. Note # of duct drops.	UNIT DOES NOT RUN
Make, Model, and Serial Number:	NO VISIBLE LABEL ON EXHAUST FAN 0.25HP 115V 5.0 AMPS 1725 RPM
Attach picture of asset.	Yes
<ul style="list-style-type: none"> • Open FuseIT2021-06-23T082150134cf72c-7cd1-4057-9acc-c5b5eeb721a8.jpg 	
Fan CFM:	0
Fan total pressure recorded.	No
Is Fan interlocked with any other asset? if so, list:	NA
When is fan used (application) and any specific time?	NA