



Nestle (Mt Sterling, KY)

CheckList Information

| | | | |
|----------------------------------|-----------------------------------------|-----------------|--------------|
| Name : | EF-7-08 Line 6 Oven Infeed Hood Exhaust | Status : | NotSubmitted |
| Assigned Organization : | National TAB | Asset : | |
| Requesting Organization : | National TAB | | |

CheckList Item Details

| | |
|------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------|
| Observe Unit to ensure operational and no visual issues. If any observed, comment. Note # of duct drops. | Make: Greenheck Model:TB1-FS-4H23-75 Serial: 07K04450 25" DIA 621 AVG FPM 2117 CFM -.26" SP |
| Attach picture of asset. | Yes |
| <ul style="list-style-type: none"> • Open FuseIT2021-06-17T1131257ab57958-f694-494a-a7c6-29e856ba5840.jpg | |
| Fan total pressure recorded. | Yes |
| Is Fan interlocked with any other asset? if so, list: | |
| When is fan used (application) and any specific time? | |
| Make, Model, and Serial Number: | Make: Greenheck Model:TB1-FS-4H23-75 Serial: 07K04450 25" DIA 621 AVG FPM |
| Fan CFM: | 2117 CFM -.26" SP |