



## Nestle (Mt Sterling, KY)

### CheckList Information

**Name :** EF-39-93 L5 OVEN INFEED & DISCHARGE HOODS      **Status :** NotSubmitted  
**Assigned Organization :** National TAB      **Asset :**  
**Requesting Organization :** National TAB

### CheckList Item Details

Observe Unit to ensure operational and no visual issues. If any observed, comment. Note # of duct drops.	TUBEAXIAL TX FAN K15458 UTL-FAN-501 -1.17 inlet SP CFM:2361 fpm:1328 16"X16"
Attach picture of asset.	Yes
<ul style="list-style-type: none"> <li>• <a href="#">Open</a> EF-39-93.jpg</li> </ul>	
Fan total pressure recorded.	Yes
Is Fan interlocked with any other asset? if so, list:	L5 OVEN HOOD
When is fan used (application) and any specific time?	24/7 L5 OVEN HOOD
Make, Model, and Serial Number:	TUBEAXIAL TX FAN K15458 UTL-FAN-501
Fan CFM:	-1.17 inlet SP CFM:2361 fpm:1328 16"X16"