



## Nestle (Mt Sterling, KY)

### CheckList Information

<b>Name :</b>	EF-HYDRAULIC ROOM	<b>Status :</b>	NotSubmitted
<b>Assigned Organization :</b>	National TAB	<b>Asset :</b>	
<b>Requesting Organization :</b>	National TAB		

### CheckList Item Details

Observe Unit to ensure operational and no visual issues. If any observed, comment. Note # of duct drops.	NO VISUAL ISSUES. UNIT ORIGINALLY THOUGHT TO BE PAIRED WITH A SF HOWEVER UPON FURTHER INSPECTION THE SF IS JUST A VENT.
Attach picture of asset.	Yes
<ul style="list-style-type: none"> <li>• <a href="#">Open</a> File.jpg</li> </ul>	
Fan total pressure recorded.	Yes
Is Fan interlocked with any other asset? if so, list:	FAN IS STANDALONE, BUT THERE IS A VENT THAT EQUALIZES ROOM PRESSURE.
When is fan used (application) and any specific time?	USED WHEN HYDRAULIC ROOM IS HOT.
Make, Model, and Serial Number:	UNIT DATA: HARTZELL MN:69-12-WF3 9803010 MOTOR: 0.5HP 460V 1A SP:-0.29"
Fan CFM:	