



Nestle (Mt Sterling, KY)

CheckList Information

Name :	EF 30-06 OVEN MEZZ	Status :	NotSubmitted
Assigned Organization :	National TAB	Asset :	
Requesting Organization :	National TAB		

CheckList Item Details

Observe Unit to ensure operational and no visual issues. If any observed, comment. Note # of duct drops.	Squeaky belt. Sp:-.247"
Attach picture of asset.	Yes
<ul style="list-style-type: none"> • Open File.jpg 	
Fan total pressure recorded.	Yes
Is Fan interlocked with any other asset? if so, list:	Interlocked with 2 other oven mezz fans switch by door
When is fan used (application) and any specific time?	Typically always on.
Make, Model, and Serial Number:	
Fan CFM:	