



## Nestle (Mt Sterling, KY)

### CheckList Information

<b>Name :</b>	EF 30-06 OVEN MEZZ	<b>Status :</b>	NotSubmitted
<b>Assigned Organization :</b>	National TAB	<b>Asset :</b>	
<b>Requesting Organization :</b>	National TAB		

### CheckList Item Details

Observe Unit to ensure operational and no visual issues. If any observed, comment. Note # of duct drops.	Squeaky belt. Sp:-.247"
Attach picture of asset.	Yes
<ul style="list-style-type: none"> <li>• <a href="#">Open</a> File.jpg</li> </ul>	
Fan total pressure recorded.	Yes
Is Fan interlocked with any other asset? if so, list:	Interlocked with 2 other oven mezz fans switch by door
When is fan used (application) and any specific time?	Typically always on.
Make, Model, and Serial Number:	GREENHECK, MN: RBUMO-3L36-50, SN: 07K03780
Fan CFM:	10344CFM